

ARCO Alaska, Inc.
Post Office Box 360
Anchorage, Alaska 99510
Telephone 907 277 5637



November 21, 1983

Mr. Mike Johnston
Chief, Air Operations Section
Region X
1200 Sixth Avenue
Seattle, Washington 98101

Mr. Doug Lowery
Regional Supervisor
Alaska Department of
Environmental Conservation
Pouch 1601
Fairbanks, Alaska 99707

SUBJECT: Compliance Test Results - Kuparuk River Unit
PSD-X82-01
8336-AA002

Dear Sirs:

Please find a copy of the NO_x compliance tests performed on a drill site heater (DS-14) and a 14,000 HP gas-fired turbine (C2101C) on September 20 and 21, 1983. Both units are included in the Central Production Facility's (CPF-1) air quality permits. The units were tested by Chemecology Corp. of Bakersfield, California, and witnessed by Robert Russel of Pedco, representing EPA Region X.

If you have any questions, please contact me at (907) 263-4307.

Sincerely,

Alan J. Schuyler
Senior Engineer
Regulatory Compliance

AJS:tlh-0031

Attachment

cc: D. Estes, ADEC-Juneau
S. Torok, EPA-Juneau

- w/attachment
- w/attachment

USEPA REG



0000006



CHEMEOLOGY CORPORATION

18823 Porterville Hwy., Bakersfield, CA 93308 • (805) 399-9335
Mailing Address: P.O. Box 1193, Bakersfield, CA 93302

FIELD DATA SOURCE TEST

PREPARED FOR: ARCO ALASKA INC.

POST OFFICE BOX 100360

ANCHORAGE, ALASKA 99510

ATTENTION: ALAN SCHUYLER

REGARDING: NOx TESTING @ GAS FIRED HEATER
AND TURBINE IN KUPARUK OIL FIELD,
ALASKA

REGULATORY AGENCY: EPA REGION #10

PURPOSE: COMPLIANCE (PSD-X82-01)

TEST DATE: SEPTEMBER 20 & 21, 1983

UNIT TESTED: a) HEATER DS-1Y
b) TURBINE CPF-1(C2101C)

REPORT NUMBER: 1781(c)

TESTED BY: L.A. Johnson
L.A. JOHNSON

REVIEWED BY: JKS

CHEMEOLOGY CORPORATION

TABLE OF CONTENTS

<u>SECTION</u>		<u>PAGE</u>
I.	INTRODUCTION	3
II.	SUMMARY OF RESULTS	7
III.	EPA METHOD #1/2/3/4 DATA	14
	A. Field Data Results	15
	B. Methods and Equations	17
IV.	NO _x & O ₂ BY INSTRUMENT	24
	A. NO _x and O ₂ Results	25
	B. Data and Calibration Correction Forms	26
	C. Methods and Equations	33
	D. Equipment Diagrams	39
V.	FUEL ANALYSIS AND EMISSION FACTORS	40
	A. NO _x Emission Factors	41
	B. Fuel Analysis	45
	C. Methods and Equations	47
VI.	SOURCE OPERATION DATA	48
VII.	SAMPLING PORT AND POINT DESCRIPTION	57
VIII.	APPENDIX	63
	1. Example Calculations	64
	2. NO _x Emission Standard for Gas Turbine	65
	3. Test Log	71
	4. Raw Field Data	74
	5. Wet Test Equipment Calibration Data	91
	6. Instrument Calibration Data & Recorder Strip Charts	95
	7. Photos of Test Location	107

INTRODUCTION

INTRODUCTION

On September 20 and 21, 1983 Chemecology Corporation performed an emissions source test for Arco Alaska Inc. on their Drillsite Heater (Drill Station 1-Y) and Turbine Compressor Unit (CPF-1), respectively. The purpose of the test was to document compliance with EPA Region X (PSD-X82-01) by monitoring flows, NOx and O₂.

The units tested consist of a Black, Sivalls & Bryson 10 MMBtu/hr Production Heater and a General Electric 14,000 HP Compressor Train Gas Turbine located on the Kuparuk Lease, North Slope, Alaska. Both units were fired on lease natural gas and were operating under normal conditions.

Emissions of NOx and O₂ of both units were determined by using the following methods:

<u>Parameter</u>	<u>Method</u>	<u># Runs/Unit</u>
NOx	Chemiluminescent Analyzer	3
O ₂	Paramagnetic Analyzer	3
Fixed Gases	EPA Method #3	3
H ₂ O	EPA Method #4	3
Flow Rate	EPA Method #1 & #2	3
Fuel Analysis	Gas Chromatograph	1

All sampling and analysis was performed by Chemecology personnel except for the fuel samples which were analyzed by Arco's lab.

Andy Winkler, Analyzer Technician and Leslie Johnson, Stack Sampler and Project Supervisor for Chemecology Corporation performed the source test. Robert Russel, of Pedco observed the test procedures for EPA Region X. Alan Schuyler of Arco Alaska Inc. directed the testing of the Heater and Turbine.

HEATER PROCESS DESCRIPTION

The drill site heater at Drill Site 1Y is used for heating produced fluids from the sixteen oil wells which are also located on the 1Y drill pad. The fluids from these wells are commingled on site and then passed through the heater. Once the fluids have been heated, the produced fluids flow through insulated pipelines to the central production facility where oil, gas, and water are separated. To assist in the production of these wells some of the gas which was separated at the central production facility is returned to the drill sites. This gas is used as the fuel for drill site heaters and is also reinjected in various wells to assist in fluid production. The 1Y drill site heater has two stacks which provide for two separate burners and exhaust streams. The heater can modulate between 0 and 100 percent of design capacity dependent on total fluid production. During the compliance test the heater was at 50 percent of capacity.

During the test on September 20, 1983 about 29,000 barrels per day of produced fluids were being produced from Drill Site 1Y.

During the test period the measured temperature of inlet fluids to the heater was 97.5°F and the exit fluids were measured at 117.5°F. Thus the heater accounted for a 20 degree change in fluid temperature.

TURBINE PROCESS DESCRIPTION

Turbine train 'C' (C2101C) was tested on September 21 at Central Production Facility 1 (CPF-1) for compliance with NO_x emission standards. The turbine is used as a prime mover for two Dresser-Clark centrifugal compressors which compress gas in two stages from 70 to 1400 psig (pound per square inch gauge). This compressed gas is then returned to the individual drill sites to assist in the production of fluids from the wells or reinjected into the gas cap of the Kuparuk reservoir. During the test period various operating parameters were measured to determine horsepower of the unit while at specific operating conditions. Turbine speed, inlet air temperature, inlet pressure losses, exhaust stack pressure losses, compressor performance data, and fuel rate were among the parameters measured.

The shaft horsepower into the compressors was calculated to be 14800. As a double check the turbine horsepower was estimated at 14600 HP using GE turbine performance curves.

SUMMARY OF RESULTS


Arco Alaska

SUMMARY OF RESULTS: NOx Permit Conditions


<u>Unit</u>	<u>Allowable NOx Emissions</u>	<u>Actual NOx Emissions</u>
Heater DS-1Y	0.10 lb/ 10^6 Btu	0.058 lbs/ 10^6 Btu
Turbine CPF-1 (C2101C)	160 ppm @ 15% O ₂ ^{1/}	121 ppm @ 15% O ₂

1/ See Appendix 2 for calculation of this permit condition.

N0x Emissions Summary 10 MM Btu/hr Heater DS-1Y



NOx Emissions Summary 14,000 HP Turbine-C2101C CPF-1



Arco Alaska

SUMMARY OF RESULTS: NOx Emissions

Actual Conditions

<u>Source</u>	ppm	<u>English Units</u>		<u>Metric Units</u>	
		lbs/MMBtu	lbs/hr	gms/joule	grms/sec
Heater DS-1Y	56	0.058	0.43	$2.5 * 10^{-8}$	$5.4 * 10^{-2}$
Turbine CPF-1 (C2101C)	96	0.445	61.4	$1.9 * 10^{-7}$	7.7

Arco Alaska

SUMMARY OF RESULTS: Unit Operating Conditions (English Units)

<u>Unit</u>	<u>%CO₂(dry)</u>	<u>%O₂(dry)</u>	<u>%H₂O</u>	<u>Stack Temp(°F)</u>	<u>Stack Velocity (fps)</u>	<u>Volume Flow (DSCFM)</u>
Heater DS-1Y	12.2	0.1	12.3	965	18	1,080
Turbine CPF-1 (C2101C)	1.5	16.2	4.4	895	143	89,600

Arco Alaska

SUMMARY OF RESULTS: Unit Operating Conditions (Metric Units)

<u>Unit</u>	<u>%CO₂(dry)</u>	<u>%O₂(dry)</u>	<u>%H₂O</u>	<u>Stack Temp(°C)</u>	<u>Stack Velocity (mps)</u>	<u>Volume Flow (Cubic Meters/Sec)</u>
Heater DS-1Y	12.2	0.1	12.3	518	5.5	0.51
Turbine CPF-1 (C2101C)	1.5	16.2	4.4	479	44	42.3

EPA METHOD #1/2/3/4/ DATA

COMPANY: ARCO ALASKA
 UNIT: HEATER DS-1Y
 DATE: 09-20-83

EPA METHOD #1/2/3/4 FIELD DATA

SITE :

RUN# :

TIME :

	#1	#2	#3
	1620	1800	1835

V m	- Dry sampled gas volume, dcf	20.15	18.50	17.95
Y	- Meter calibration factor	0.986	0.986	0.986
P-bar	- Barometric pressure, in Hg	29.92	29.92	29.92
P-static	- Stack static pressure, in H2O	-0.08	-0.06	-0.08
delta-H	- Differential meter press, in H2O	0.00	0.00	0.00
T m	- Meter temperature, deg R	505	498	497
Vm(std)	- Std sampled gas volume, dscf	20.78	19.35	18.81

V lc	- Volume of water collected, gms	75.3	45.2	59.5
B ws	- Water vapor fraction	0.144	0.098	0.128
MF	- Moisture factor	0.856	0.902	0.872

CO2	- % dry volume	12.0	12.3	12.4
O2	- % dry volume	0.0	0.0	0.0
N2	- % dry volume	88.0	87.7	87.6
MW-dry	- Dry molecular weight	29.92	29.97	29.98
MW-wet	- Wet molecular weight	28.20	28.80	28.45

C p	- Pitot tube coefficient	0.80	0.80	0.80
$\sqrt{\Delta P}$	- Avg[sqrt(Pitot readings)], "H2O	0.17	0.22	0.20
T s	- Stack temperature, deg R	1425	1430	1420
V s	- Stack velocity, ft/sec	15.4	19.7	17.7

A s	- Stack area, sq.ft.	3.14	3.14	3.14
Q s	- Std volumetric flow rate, dscfm	919	1236	1079

COMPANY: ARCO ALASKA
 UNIT: TURBINE CPF-1 (C2101C)
 DATE: 09-21-83

EPA METHOD #1/2/3/4 FIELD DATA

SITE :

RUN# :

TIME :

#1 #2 #3
1120 1215 1355

V m	- Dry sampled gas volume, dcf	21.00	20.10	20.56
Y	- Meter calibration factor	0.986	0.986	0.986
P-bar	- Barometric pressure, in Hg	29.65	29.65	29.65
P-static	- Stack static pressure, in H2O	0.70	0.76	0.70
delta-H	- Differential meter press, in H2O	0.00	0.00	0.00
T m	- Meter temperature, deg R	505	505	505
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
Vm(std)	- Std sampled gas volume, dscf	21.46	20.54	21.01
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>

V lc	- Volume of water collected, gms	15.5	22.3	25.4
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
B ws	- Water vapor fraction	0.032	0.048	0.053
MF	- Moisture factor	0.968	0.952	0.947
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>

CO2	- % dry volume	1.5	1.5	1.4
O2	- % dry volume	16.5	16.6	16.5
N2	- % dry volume	82.0	81.9	82.1
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
MW-dry	- Dry molecular weight	28.90	28.90	28.88
MW-wet	- Wet molecular weight	28.55	28.38	28.31
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>

C p	- Pitot tube coefficient	0.80	0.80	0.80
\delta P	- Avg[sqrt(Pitot readings)], "H2O	1.64	1.66	1.64
T s	- Stack temperature, deg R	1350	1355	1355
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
V s	- Stack velocity, ft/sec	141.8	144.3	142.1
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>

A s	- Stack area, sq.ft.	28.27	28.27	28.27
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
Q s	- Std volumetric flow rate, dscfm	90338	90130	88287
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>

INITIAL MOLECULAR WEIGHT AND PERCENT WATER

REF: EPA, Code of Federal Regulations, Title 40, Part 60, Appendix A,
Method 3 and 4, 1981
: Conner, W. D. and J. S. Nader, Air Sampling with Plastic Bags, JAIPA
25:291-297, May - June, 1964

MOLECULAR WEIGHT:

Sampling Procedure:

A stainless steel probe with glass wool plug was inserted into the duct. A hand pump or an electric peristaltic pump was attached to the probe, followed by a rubber bladder sample container. The sampling lines were flushed with sample, then the bladder was filled by pumping duct gases into the bladder.

Analytical Procedure:

The bladder was analyzed by Orsat for dry percent CO₂, O₂ and N₂. The bulb of the analyzer was flushed with sample then filled at ambient temperature and pressure. Carbon dioxide was determined by absorption in potassium hydroxide; oxygen in Oxsorbent and nitrogen by difference. Replicate runs were made until agreement was reached. When indicated, ppm range CO was determined by Präzger tube.

PERCENT WATER:

Procedure 1: (EPA, Method 4, Condensation Method)

A tared condenser and drying tube were inserted in place of the spent molecular weight apparatus. Where possible the probe was heated above 225°F. A dry gas meter was attached downstream of the pump. Sampling was maintained at a constant rate of approximately 0.5 CFM. Percent water was determined by the increase in weight at the condenser and drying tube plus the meter data.

Procedure 2: (Saturated Duct Gas)

When at or above saturation, gaseous percent water was calculated directly from the average duct temperature and pressure by psychrometry.

Procedure 3: (Wet-Dry Bulb)

Two thermometers, one within a water saturated wick, were inserted into the duct gas stream. At equilibrium the two temperatures were recorded. Gaseous percent water was calculated from the wet and dry bulb temperatures by psychrometry.

VELOCITY TRAVERSE AND VOLUME FLOW RATE

- REF: Environmental Protection Agency, Code of Federal Regulations,
Title 40, Part 60, Appendix A, Method 1 and 2, 1981
: Bay Area AQMD, Manual of Procedures, San Francisco, CA, Method St-17
January, 1982
: ASME Performance Test Code #27, New York, NY, 1957
: ASTM D-2928-71
: Western Precipitation Division of Joy Manufacturing, WP-50, 1968

PROCEDURE:

Duct temperature and velocity were read at each of several traverse points 1/ within the duct. The number and location of traverse points was chosen to aid in the extraction of a representative sample (i.e. by EPA Method 1). Velocity head was determined using a calibrated type "S" pitot tube and Magnehelic differential pressure gauge. Duct temperature was measured by means of a thermocouple attached to the pitot tube. Static pressure was measured with the Magnehelic and one leg of the pitot tube. Using the molecular weight and traverse data, velocity was calculated at each traverse point. From the average velocity, duct area, temperature, pressure and composition, actual and standard gas volume flow rate were calculated for the duct.

CALCULATIONS:

Performed by computer based on the following equations:

1/ Duct temperature was not measured at each traverse point. A temperature probe was inserted at each port and used for each traverse.

METHOD 2 STACK GAS VELOCITY AND VOLUMETRIC FLOWRATE

Average Stack Gas Velocity

$$P_g = \frac{\text{Static Pressure, "H}_2\text{O}"}{13.6}$$

$$P_s = P_{bar} + P_g \quad \text{Eq. 2-6}$$

$$v_s = K_p C_p (\sqrt{\Delta p}) \text{ avg} \sqrt{\frac{T_s(\text{avg})}{P_s M_s}} \quad \text{Eq. 2-9}$$

Average Stack Gas Dry Volumetric Flow Rate

$$Q_{std} = 60 (1-B_{ws}) v_s A \left(\frac{T_{std}}{T_s(\text{avg})} \right) \left(\frac{P_s}{P_{std}} \right) \quad \text{Eq. 2-10}$$

$$\frac{Q_{std}}{MF} = \text{scfm}$$

METHOD 3 DRY MOLECULAR WEIGHT OF STACK GAS

$$M_d = 0.440 (\%CO_2) + 0.320 (\%O_2) + 0.280 (\%N_2 + \%CO) \quad \text{Eq. 3-2}$$

Wet Molecular Weight of Stack Gas

$$M_s = M_d (1-B_{ws}) + 18 (B_{ws})$$

METHOD 4 DETERMINATION OF MOISTURE CONTENT IN STACK GASES (Use when a moisture train is run separately from other pollutant measurements.)

Volume of Water Vapor Condensed

$$V_{wc(\text{std})} = \frac{(V_f - V_i) P_w R T_{\text{std}}}{P_{\text{std}} M_w} = K_1 (V_f - V_i) \quad \text{Eq. 4-1}$$

Where $K_1 = 0.04646 \text{ ft}^3/\text{ml} @ 520^\circ\text{R}$
 $0.04717 @ 528^\circ\text{R}$

Volume of Water Vapor Collected in Silica Gel

$$V_{wsg(\text{std})} = \frac{(W_f - W_i) R T_{\text{std}}}{P_{\text{std}} M_w (453.6 \text{ g/lb})} = K_2 (W_f - W_i) \quad \text{Eq. 4-2}$$

Where $K_2 = 0.04651 \text{ ft}^3/\text{g} @ 520^\circ\text{R}$
 $0.04723 @ 528^\circ\text{R}$

Sample Gas Volume

$$V_m(\text{std}) = V_m Y \frac{(P_m)(T_{\text{std}})}{(P_{\text{std}})(T_m)} = K_3 Y \frac{V_m P_m}{T_m} \quad \text{Eq. 4-3}$$

Where $K_3 = 17.38 \text{ } ^\circ\text{R}/\text{in Hg} @ 520^\circ\text{R}$
 $17.65 @ 528^\circ\text{R}$

Moisture Content

$$B_{ws} = \frac{V_{wc(\text{std})} + V_{wsg(\text{std})}}{V_{wc(\text{std})} + V_{wsg(\text{std})} + V_m(\text{std})} \quad \text{Eq. 4-4}$$

$B_{ws} \times 100 = \% \text{ H}_2\text{O in gas stream}$


MF = $1 - B_{ws}$

NOMENCLATURE

A	=	Cross-sectional area of stack (ft^2)
A_n	=	Cross-sectional area of nozzle, (ft^2)
B_{ws}	=	Proportion of water vapor, by volume, in the gas stream
C_a	=	Acetone blank residue concentration, (mg/g)
C_p	=	Pitot tube coefficient, dimensionless
C_s	=	Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, (gr/dscf)
C_{SO_2}	=	Concentration of sulfur dioxide, dry basis corrected to standard conditions, (lb/dscf)
$C_{H_2SO_4}$	=	Sulfuric acid (including SO_3) concentration, corrected to standard conditions, (lb/dscf)
ΔH	=	Average pressure differential across the orifice meter, (in H_2O)
K_p	=	Pitot tube constant, $85.49 \frac{\text{ft}}{\text{sec}} \left[\frac{(1\text{b}/1\text{b-mole})(\text{in Hg})^{1/2}}{(R)(\text{in } H_2O)} \right]$
L_p	=	Leakage rate observed during the post-test leak check, (cfm)
L_a	=	Maximum acceptable leakage rate, (0.02 cfm or 4% of average sampling rate, whichever is less)
L_i	=	Individual leakage rate observed during the leak check conducted prior to the "ith" component change, (cfm)
m_a	=	Mass of residue of acetone after evaporation, mg.
M_d	=	Molecular weight of stack gas, dry basis, (lb/lb-mole)
m_n	=	Total weight of particulate matter collected, mg.
M_s	=	Molecular weight of stack gas, wet basis, (lb/lb-mole)
M_w	=	Molecular weight of water, 18 lb/lb-mole
N	=	Normality of barium perchlorate titrant, (milliequivalents/ml)
Δp	=	Velocity head of stack gas, (in. H_2O)
P_{bar}	=	Barometric pressure at measurement site (in Hg)
P_g	=	Stack static pressure, (in Hg)
P_m	=	Absolute pressure at the dry gas meter
P_s	=	Absolute stack gas pressure, (in Hg)
P_{std}	=	Standard absolute pressure, 29.92 in Hg
Q_{std}	=	Dry volumetric stack gas flow rate, standard conditions, (dscfm)
R	=	Ideal gas constant, $21.85 (\text{in Hg})(\text{ft}^3)/(1\text{b-mole})(^\circ R)$
t_s	=	Stack temperature, ($^\circ F$)
T_m	=	Absolute temperature at meter, ($^\circ R$)
T_{std}	=	Standard Absolute temperature, ($520^\circ R$)
T_s	=	Absolute stack temperature, ($460^\circ + t_s$)
V_a	=	Volume of sample aliquot titrated, (ml)
$V_{ab.}$	=	Volume of acetone blank, ml
V_m	=	Dry gas volume measured by dry gas meter, (dcf)
$V_{m(std)}$	=	Dry gas volume measured by dry gas meter, corrected to standard conditions, (dscf)
$V_{wc(std)}$	=	Volume of water vapor condensed corrected to standard

		conditions, (scf)
$V_{wsg}(\text{std})$	=	Volume of water vapor collected in silica gel corrected to standard conditions (scf)
V_{1c}	=	Volume of water vapor condensed in impingers and silica gel, (ml)
V_f	=	Final volume of condensed water, ml
V_i	=	Initial volume of condensed water, ml
v_s	=	Average stack gas velocity, (ft/sec)
V_{soln}	=	Total volume of solution in which the sulfur dioxide sample is contained (ml)
V_t	=	Volume of barium perchlorate titrant used for the sample, (ml)
V_{tb}	=	Volume of barium perchlorate titrant used for the blank, (ml)
W_f	=	Final weight of silica gel or silica gel plus impinger, (g)
W_i	=	Initial weight of silica gel or silica gel plus impinger, (g)
γ	=	Dry gas meter calibration factor
P_w	=	Density of water, (0.002202 lb/ml @ 60°F)
P_a	=	Density of acetone, (g/ml)(see bottle label)
MF	=	Moisture factor
%CO ₂	=	Percent CO ₂ by volume (dry basis)
%O ₂	=	Percent O ₂ by volume (dry basis)
%CO	=	Percent CO by volume (dry basis)
%N ₂	=	Percent N ₂ by volume (dry basis)
0.264	=	Ratio of O ₂ to N ₂ in air v/v
0.280	=	Molecular weight of N ₂ or CO, divided by 100
0.320	=	Molecular weight of O ₂ , divided by 100
0.440	=	Molecular weight of CO ₂ , divided by 100
60	=	Conversion factor, (sec/min)
18.0	=	Molecular weight of water, (1b/1b-mole)
32.03	=	Equivalent weight of sulfur dioxide
θ	=	Total sampling time (min)
θ_1	=	Sampling time interval, from the run beginning until first component change, (min)
θ_i	=	Sampling time interval, between two successive component changes, beginning with the interval between the first and second changes, (min)
θ_p	=	Sampling time interval, from the final (n th) component change until the end of the sampling run, (min)

EPA Method #4
Condensation Train

Impinger #

1
2
3
4
5

Contents

100 mls	Distilled Water
50 mls	Distilled Water
50 mls	Distilled Water
Empty	
200-300 grms	Silica Gel

NO_x & O₂ BY INSTRUMENTATION

Arco Alaska

NOx & O₂ INSTRUMENT RESULTS

<u>Unit</u>	<u>Date</u>	<u>Run #</u>	<u>Time</u>	<u>%O₂</u>	<u>ppm NOx</u>	<u>SDCFM</u>	<u>1bs/hr</u>	<u>ppm corrected to 15% O₂</u>
Heater 1-Y	9-20-83	1	16:45-17:15	0.1	53	920	0.35	-
		2	18:20-18:50	0.1	58	1,240	0.52	-
		3	19:05-19:35	0.1	56	1,080	0.43	-
			Average:	0.1	56	1,080	0.43	
Turbine CPF-1 C2101C	9-21-83	1A	11:15-12:00	16.1	94	90,300	60.8	116
		1B	12:20-13:05	16.3	96	90,300	62.1	123
		2	13:35-14:05	16.2	95	90,100	61.3	119
		3	14:20-14:50	16.3	97	88,300	61.3	124
			Average: 1/	16.2	96	89,600	61.4	121

1/ Note: Averages for turbine are calculated with Run 1A and 1B as a single test run.

COMPANY: ARCO ALASKA
 UNIT NAME: HEATER DS-1Y
 TEST DATE: 09-20-83

INSTRUMENT RUN #1

INTERVAL	START	FINISH	O2(%)	NOx (ppm)
#1	16.45	16.50	0.2	93.2
#2	16.50	16.55	0.1	93.0
#3	16.55	17.00	0.1	92.9
#4	17.00	17.05	0.1	93.7
#5	17.05	17.10	0.1	93.6
#6	17.10	17.15	0.0	93.4
AVERAGE:	16.45	17.15	0.1	93.3
Units:			(%)	(ppm)

CALIBRATION DATA:

Initial ZERO	0.0	0.0
Initial SPAN	21.0	92.0
Final ZERO	0.2	1.0
Final SPAN	21.0	93.0
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
ZERO DRIFT (% of SPAN)	1.0%	1.1%
SPAN DRIFT (% of SPAN)	-1.0%	0.0%
ZERO DRIFT (% of RANGE)	0.8%	0.2%
SPAN DRIFT (% of RANGE)	-0.8%	0.0%

COMPANY: ARCO ALASKA
 UNIT NAME: HEATER DS-1Y
 TEST DATE: 09-20-83

INSTRUMENT RUN #2

INTERVAL	START	FINISH	O2 (%)	NOx (ppm)
#1	18.20	18.25	0.1	56.2
#2	18.25	18.30	0.1	57.1
#3	18.30	18.35	0.1	57.1
#4	18.35	18.40	0.1	57.1
#5	18.40	18.45	0.1	58.1
#6	18.45	18.50	0.0	59.1
AVERAGE:	18.20	18.50	0.1	57.5
Units:			(%)	(ppm)

CALIBRATION DATA:

Initial ZERO	0.1	1.0
Initial SPAN	20.9	93.0
Final ZERO	0.2	3.0
Final SPAN	21.0	92.0
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
ZERO DRIFT (% of SPAN)	0.5%	2.2%
SPAN DRIFT (% of SPAN)	0.0%	-3.3%
ZERO DRIFT (% of RANGE)	0.4%	0.4%
SPAN DRIFT (% of RANGE)	0.0%	-0.6%

COMPANY: ARCO ALASKA
 UNIT NAME: HEATER DS-1Y
 TEST DATE: 09-20-83

INSTRUMENT RUN #3

INTERVAL	START	FINISH	O2 (%)	NOx (ppm)
#1	19.05	19.10	0.1	55.0
#2	19.10	19.15	0.1	55.9
#3	19.15	19.20	0.1	55.8
#4	19.20	19.25	0.0	55.6
#5	19.25	19.30	0.0	55.5
#6	19.30	19.35	0.0	55.3
AVERAGE:	19.05	19.35	0.1	55.5
Units:		(%)		(ppm)

CALIBRATION DATA:

Initial ZERO	0.0	0.0
Initial SPAN	20.9	92.0
Final ZERO	0.1	1.0
Final SPAN	21.0	93.0
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
ZERO DRIFT (% of SPAN)	0.5%	1.1%
SPAN DRIFT (% of SPAN)	0.0%	0.0%
ZERO DRIFT (% of RANGE)	0.4%	0.2%
SPAN DRIFT (% of RANGE)	0.0%	0.0%

COMPANY: ARCO ALASKA
 UNIT NAME: TURBINE CPF-1 (C2101C)
 TEST DATE: 09-21-83

INSTRUMENT RUN #1A

INTERVAL	START	FINISH	O2(%)	NOx (ppm)
#1	11.15	11.20	16.2	94.8
#2	11.20	11.25	16.2	93.5
#3	11.25	11.30	16.1	93.1
#4	11.30	11.35	16.1	93.6
#5	11.35	11.40	16.2	94.2
#6	11.40	11.45	16.1	93.8
#7	11.45	11.50	16.1	93.5
#8	11.50	11.55	16.1	93.1
#9	11.55	12.00	16.1	93.6
AVERAGE:	11.15	12.00	16.1	93.7
Units:			(%)	(ppm)

CALIBRATION DATA:

Initial ZERO	0.0	0.0
Initial SPAN	20.8	96.0
Final ZERO	0.3	4.0
Final SPAN	21.3	100.0
<hr/>		
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
<hr/>		
ZERO DRIFT (% of SPAN)	1.4%	4.2%
SPAN DRIFT (% of SPAN)	1.0%	0.0%
<hr/>		
ZERO DRIFT (% of RANGE)	1.2%	0.8%
SPAN DRIFT (% of RANGE)	0.8%	0.0%

COMPANY: ARCO ALASKA
 UNIT NAME: TURBINE CPF-1 (C2101C)
 TEST DATE: 09-21-83

INSTRUMENT RUN #1B

INTERVAL	START	FINISH	O2(%)	NOx (ppm)
#1	12.20	12.25	16.3	97.8
#2	12.25	12.30	16.3	96.4
#3	12.30	12.35	16.4	92.1
#4	12.35	12.40	16.3	92.7
#5	12.40	12.45	16.2	96.2
#6	12.45	12.50	16.2	98.7
#7	12.50	12.55	16.2	97.3
#8	12.55	13.00	16.3	95.9
#9	13.00	13.05	16.3	97.5
AVERAGE:	12.20	13.05	16.3	96.1
Units:			(%)	(ppm)

CALIBRATION DATA:

Initial ZERO	0.0	1.0
Initial SPAN	21.0	95.0
Final ZERO	0.5	2.0
Final SPAN	21.4	99.0
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
ZERO DRIFT (% of SPAN)	2.4%	1.1%
SPAN DRIFT (% of SPAN)	-0.5%	3.2%
ZERO DRIFT (% of RANGE)	2.0%	0.2%
SPAN DRIFT (% of RANGE)	-0.4%	0.6%

COMPANY: ARCO ALASKA
 UNIT NAME: TURBINE CPF-1 (C2101C)
 TEST DATE: 09-21-83

INSTRUMENT RUN # 2

INTERVAL	START	FINISH	O2(%)	NOx (ppm)
#1	13.35	13.40	16.2	95.3
#2	13.40	13.45	16.2	96.4
#3	13.45	13.50	16.2	95.6
#4	13.50	13.55	16.2	94.8
#5	13.55	14.00	16.2	94.0
#6	14.00	14.05	16.2	94.1
AVERAGE:	13.35	14.05	16.2	95.0
Units:			(%)	(ppm)

CALIBRATION DATA:

Initial ZERO	0.0	0.0
Initial SPAN	21.0	96.0
Final ZERO	0.2	0.0
Final SPAN	21.0	95.0
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
ZERO DRIFT (% of SPAN)	1.0%	0.0%
SPAN DRIFT (% of SPAN)	-1.0%	-1.0%
ZERO DRIFT (% of RANGE)	0.8%	0.0%
SPAN DRIFT (% of RANGE)	-0.8%	-0.2%

COMPANY: ARCO ALASKA
 UNIT NAME: TURBINE CPF-1 (C2101C)
 TEST DATE: 09-21-83

INSTRUMENT RUN # 3

INTERVAL	START	FINISH	O2(%)	NOx (ppm)
#1	14.20	14.25	16.3	98.3
#2	14.25	14.30	16.3	97.5
#3	14.30	14.35	16.3	96.6
#4	14.35	14.40	16.3	96.8
#5	14.40	14.45	16.3	96.9
#6	14.45	14.50	16.3	96.1
AVERAGE:	14.20	14.50	16.3	97.0
Units:			(%)	(ppm)

CALIBRATION DATA:

Initial ZERO	0.0	0.0
Initial SPAN	21.0	95.0
Final ZERO	0.2	0.0
Final SPAN	21.0	94.0
RANGE (full scale, % or ppm)	25	500
SPAN GAS VALUE (% or ppm)	20.9	92.3
ZERO DRIFT (% of SPAN)	1.0%	0.0%
SPAN DRIFT (% of SPAN)	-1.0%	-1.1%
ZERO DRIFT (% of RANGE)	0.8%	0.0%
SPAN DRIFT (% of RANGE)	-0.8%	-0.2%

CONSTANT MONITORING

REF: Bay Area AQMD, Manual of Procedures, San Francisco, CA, Methods ST-5, ST-6, ST-13A, ST-14, ST-19A, January, 1982
: State of California, Air Resources Board, Draft Stationary Source Test Methods, Method 1-100, June, 1979

METHOD SUMMARY:

A representative sample of duct gas was extacted through a probe, filter, condenser and sample line by a pump. The sample was then pumped into a sampling manifold for distribution to one or more sample analyzers. The analyzers output a continuous analog recording of the concentrations of the analyzed gases in the sample. All analyzers were calibrated with EPA Protocol gases (traceable to National Bureau of Standards SRMs) or with recently analyzed gases (analysis by EPA Reference Methods).

SAMPLING SYSTEM:

A Pyrex glass or stainless steel probe with a Pyrex wool or glass fibre mat filter was positioned in the duct. The end of the probe was located at a point of average duct flow and average pollutant concentrations. The probe was connected with a short (about 2 feet) Teflon line to a sample conditioning train. The conditioning train included three glass knockout traps connected in series with Teflon lines and immersed in an ice bath. The train was connected with a Teflon line ($\frac{1}{4}$ inch o.d.) to the pneumatic delivery system which was housed in the monitoring van.

PNEUMATIC DELIVERY SYSTEM:

The Teflon sample line delivered sample gas into a small glass knockout trap, then through an in-line Balston filter and a Hoke four-way selector valve to the Teflon-lined diaphragm sample pump (see accompanying diagram). The flow rate of the sample gas was regulated with main and bypass-flow needle valves and was read on the main flow meter (typical setting 10 SCFH). A 10 PSI pressure-relief valve kept the entire system pressure at a safe level. The manifold pressure was regulated with an exhaust needle valve and was read on the pressure gauge (typical setting 1 PSI). The sample in the manifold was delivered through needle valves and flow meters to the various analyzers.

LEAK CHECK PROCEDURE:

The sampling system was checked for leaks by plugging the end of the probe. The exhaust needle valve was closed and the entire sample flow was directed through one analyzer flow meter (range 0-1.0 SCFH). The bypass valve was closed until the vacuum gauge showed at least 15 inches Hg vacuum. The leak rate was observed at the analyzer flow meter (maximum allowable 2% of total sample flow). The system was checked for leaks before and after sampling.

CONSTANT MONITORING

CALIBRATION PROCEDURE:

Each analyzer was calibrated before and after each sample run. The Hoke four-way selector valve was used to direct the flow of the various calibration gases into the sample manifold. Each analyzer was calibrated with a zero gas (typically, ambient air or zero grade Nitrogen) and with a span gas (typical span gas concentration 60 to 90 percent of analyzer full scale and/or similar to expected sample concentration). All zero and span checks were recorded and noted on the recorder strip charts.

STRIP CHART DATA REDUCTION:

The analog recordings were averaged over time periods as shown on the data pages (typically 5 minutes, 15 minutes or 30 minutes). The data for each averaging period was digitized and recorded as average percent of full scale. These sample readings were then compared with the zero and span gas readings for calculation of the average concentration for each averaging period.

Any drift^{1/} of the zero and span readings from the beginning to the end of a sampling period was corrected by calculating apparent zero and span readings for the midpoint of each averaging period. The sample average concentrations were then calculated from the sample readings and the apparent zero and span readings.

Instrument Data Reduction

Ref: State of California, Air Resources Board, Draft Stationary Source Test Methods, Method 1-100, June 1979

Definitions:

Z_0 = initial zero reading (% full scale)
 S_0 = initial span reading (% full scale)
 Z_f = final zero reading (%full scale)
 S_f = final span reading (% full scale)
 n = total # of intervals
 i = identifier for i^{th} interval
 ΔZ = zero drift (% full scale)
 ΔS = span drift (% full scale)
Range = ppm or % pollutant at 100% full scale
 Z_i = calculated zero at mid-point of i^{th} interval (% full scale)
 S_i = calculated span at mid-point of i^{th} interval (% full scale)
 R_i = average pollutant reading for i^{th} interval (% full scale)
 C_i = drift corrected pollutant reading for i^{th} interval (ppm or %)
 SGV = span gas value (ppm or %)

Equations:

$$\Delta Z = Z_f - Z_0$$

$$\Delta S = S_f - S_0$$

$$Z_i = Z_0 + i * (Z_f - Z_0)/(n + 1)$$

$$S_i = S_0 + i * (S_f - S_0)/(n + 1)$$

$$C_i = (R_i - Z_i)/(S_i - Z_i) * SGV$$

EPA Method 20

Ref: EPA, Code of Federal Regulations; Title 40, Part 60, Appendix A, Method 20, 1981.

Method Summary:

The preliminary test were performed on the analyzer sampling system on day 1 or both days as indicated:

- 1) Systems Calibration Check - Both Days
- 2) NO/NO₂ Converter Check - Day 1
- 3) Response Time through entire sampling system - Day 1

Spanning and zeroing of the NOx and O₂ analyzers was done before and after each run. Ambient air drawn through Drierite was used for the NOx zero and the Oxygen span. An EPA Protocol gas (CAL-7232) was used to span the NOx analyzer and zero the Oxygen analyzer.

An oxygen stack traverse was performed on both the heater (1Y) and the Turbine (CPF-1). This traverse was done using the same sample points as the velocity profile. For the Turbine (CPF-1) the oxygen traverse was used as run number one (1A and 1B): traversing both ports, sampling for a minimum six (6) minutes per point, 12 points (1.5 minute response time plus 1 minute sampling). After proving no oxygen stratification exist two (2) additional thirty (30) minute runs were executed by sampling at eight selected points.

CONSTANT MONITORINGANALYZERS:Taylor Servomex OA250 or OA580 Oxygen Analyzer

The Taylor paramagnetic analyzer is used to measure the percent dry volume of oxygen in the sample gas. This analyzer contains a quartz-glass "dumb-bell" that is filled with nitrogen and suspended in a non-uniform magnetic field. The spheres at the ends of the dumb-bell are repelled from the strongest part of the field by their diamagnetic property. The dumb-bell therefore rotates to a position where the repellent force and the torque-resistance of the suspension are in equilibrium.

The sample gas flows into a sample cell which encases the dumb-bell. The paramagnetism of any oxygen in the sample gas reduces the intensity of the field and therefore alters the position of the dumb-bell. A small mirror at the center of the dumb-bell reflects a beam of light onto twin photocells (see schematic diagram). The output of the photocells is amplified and fed back to a coil around the dumb-bell. The current required to keep the dumb-bell at the zero position is a direct measure of the magnetic force and is therefore a measure of the oxygen content of the sample gas.




Fig. 1. Taylor Servomex Oxygen Cell
— Schematic using Munday's
principles




Fig. 2. Taylor Servomex Oxygen
Analyser — Schematic


CONSTANT MONITORINGANALYZERS:Monitor Labs 8430 Nitrogen Oxides Analyzer

The Monitor Labs chemiluminescent analyzer is used to measure parts per million dry volume of Nitrogen Oxides in the sample gas. The analyzer measures the concentration of NO_x by converting NO_x to NO and then measuring the light emitted by the reaction of NO with ozone.

The sample gas is drawn into the analyzer by a vacuum pump which partially evacuates the reaction chamber. The sample flows through a NO₂-to-NO converter^{1/} for NO_x analysis or may bypass the converter for NO analysis. The sample then flows through a temperature controlled critical orifice into the partially evacuated reaction chamber.

Ambient air is also drawn into the analyzer as an ozone carrier. The air flows through a desiccant cartridge for drying, then through an ozone generator which converts some of the oxygen in the air to ozone. The ozonated air then flows through a temperature-controlled critical orifice into the reaction chamber.


The sample gas and the ozonated air are mixed in the reaction chamber, where the following reaction takes place:



The intensity of the chemiluminescence is proportional to the concentration of NO in the reaction chamber. The light emitted by this chemiluminescent reaction shines through a window in the chamber onto a photomultiplier tube (PMT). A spinning light chopper wheel between the reaction chamber and the PMT allows the PMT output with no light to be compared electronically with the PMT output with light. The signal is processed electronically and output for recording of the concentration of NO (or NO_x if the converter is used).

1/ Either of two types of converter may be used-a 300°C Molybdenum-catalyst converter or a 900°C stainless steel converter.

CONSTANT MONITOR
Pneumatic System



FUEL ANALYSIS & EMISSION FACTORS

COMPANY: ARCO ALASKA, Inc.
 UNIT ID: HEATER DS-1Y
 DATE: 09-20-83

FUEL ANALYSIS & EMISSION FACTORS

POLLUTANT	% O2	PPM(dry)	LBS/DSCF	LBS/MMBTU
NOx RUN #1	0.1	53	6.33E-06	0.055
NOx RUN #2	0.1	58	6.92E-06	0.060
NOx RUN #3	0.1	56	6.69E-06	0.058
NOx AVERAGE	0.1	56	6.65E-06	0.058

FUEL GAS:	% H	% C	% S	% N	% O	Btu/lb	SDCF/MMBtu
Lease Gas	22.61	75.53	0.00	0.32	1.54	22648	8707

COMPANY: ARCO ALASKA, Inc.
 UNIT ID: TURBINE CPF-1 (C2101C)
 DATE: 09-21-83

FUEL ANALYSIS & EMISSION FACTORS

POLLUTANT	% O2	PPM(dry)	LBS/DSCF	LBS/MMBTU
NOx RUN #1	16.2	95	1.13E-05	0.439
NOx RUN #2	16.2	95	1.13E-05	0.439
NOx RUN #3	16.3	97	1.16E-05	0.458
NOx AVERAGE	16.2	96	1.14E-05	0.445

$$96 \text{ ppm} \left(\frac{20.9 - 15}{20.9 - 16.2} \right) = 121 \text{ ppm}$$

FUEL :	% H	% C	% S	% N	% O	Btu/lb	SDCF/MMBtu
Lease Gas	22.49	75.65	0.00	0.31	1.55	22596	8716

Company: ARCO ALASKA, INC
 Unit: HEATER DS-1Y
 Date: 09-20-83

F FACTOR FOR GASEOUS FUEL

COMPONENT	C	H	EXPAND	MOLE %	MW	MW°	WT. %	% C	% H	% N	% O
O2	0	0	1.000	0.000	32	0.00	0.00	0.00	0.00	0.00	0.00
N2	0	0	1.000	0.220	28	0.06	0.32	0.00	0.00	0.32	0.00
CO2	0	0	1.000	0.940	44	0.41	2.12	0.58	0.00	0.00	1.54
CO	1	0	2.893	0.000	28	0.00	0.00	0.00	0.00	0.00	0.00
H2	0	2	1.892	0.000	2	0.00	0.00	0.00	0.00	0.00	0.00
C1	1	4	8.569	85.340	16	13.65	69.90	52.43	17.48	0.00	0.00
C2	2	6	15.246	7.190	30	2.16	11.04	8.83	2.21	0.00	0.00
C2=	2	4	13.354	0.000	28	0.00	0.00	0.00	0.00	0.00	0.00
C3	3	8	21.923	3.780	44	1.66	8.51	6.97	1.55	0.00	0.00
C3=	3	6	20.031	0.000	42	0.00	0.00	0.00	0.00	0.00	0.00
C4	4	10	28.600	1.810	58	1.05	5.37	4.45	0.93	0.00	0.00
C4=	4	8	26.708	0.000	56	0.00	0.00	0.00	0.00	0.00	0.00
C5	5	12	35.277	0.550	72	0.40	2.03	1.69	0.34	0.00	0.00
C5=	5	10	33.385	0.000	70	0.00	0.00	0.00	0.00	0.00	0.00
C6+	6	14	41.954	0.160	86	0.14	0.70	0.59	0.11	0.00	0.00
TOTAL	-	-	-	99.990	-	19.53	100.00	75.53	22.61	0.32	1.54

COMPONENT	WT. %
CARBON	75.53
HYDROGEN	22.61
NITROGEN	0.32
OXYGEN	1.54
SULFER	0.00

SPECIFIC GRAVITY, (AIR=1) @ 60° F 0.678
 SPECIFIC VOLUME, scf/LB @ 60° F 19.31
 GROSS CALORIFIC VALUE, BTU/scf @ 60° F 1173
 GROSS CALORIFIC VALUE, BTU/LB 22648

EPA F-FACTOR @ 68° F 8707 DSCF/MMBTU

Company: ARCO ALASKA, INC
 Unit: TURBINE CPF-1 (C2101C)
 Date: 09-21-83

F FACTOR FOR GASEOUS FUEL

COMPONENT	C	H	EXPAND	MOLE %	MW	MW°	WT. %	% C	% H	% N	% O
O2	0	0	1.000	0.000	32	0.00	0.00	0.00	0.00	0.00	0.00
N2	0	0	1.000	0.220	28	0.06	0.31	0.00	0.00	0.31	0.00
CO2	0	0	1.000	0.960	44	0.42	2.13	0.58	0.00	0.00	1.55
CO	1	0	2.893	0.000	28	0.00	0.00	0.00	0.00	0.00	0.00
H2	0	2	1.892	0.000	2	0.00	0.00	0.00	0.00	0.00	0.00
C1	1	4	8.569	84.160	16	13.47	67.97	50.98	16.99	0.00	0.00
C2	2	6	15.246	7.730	30	2.32	11.71	9.36	2.34	0.00	0.00
C2=	2	4	13.354	0.000	28	0.00	0.00	0.00	0.00	0.00	0.00
C3	3	8	21.923	4.210	44	1.85	9.35	7.65	1.70	0.00	0.00
C3=	3	6	20.031	0.000	42	0.00	0.00	0.00	0.00	0.00	0.00
C4	4	10	28.600	2.000	58	1.16	5.86	4.85	1.01	0.00	0.00
C4=	4	8	26.708	0.000	56	0.00	0.00	0.00	0.00	0.00	0.00
C5	5	12	35.277	0.570	72	0.41	2.07	1.73	0.35	0.00	0.00
C5=	5	10	33.385	0.000	70	0.00	0.00	0.00	0.00	0.00	0.00
C6+	6	14	41.954	0.140	86	0.12	0.61	0.51	0.10	0.00	0.00
TOTAL	-	-	-	99.990	-	19.81	100.00	75.65	22.49	0.31	1.55

COMPONENT	WT. %
CARBON	75.65
HYDROGEN	22.49
NITROGEN	0.31
OXYGEN	1.55
SULFER	0.00

SPECIFIC GRAVITY, (AIR=1) @ 60° F	0.688
SPECIFIC VOLUME, scf/LB @ 60° F	19.04
GROSS CALORIFIC VALUE, BTU/scf @ 60° F	1187
GROSS CALORIFIC VALUE, BTU/LB	22596

EPA F-FACTOR @ 68° F

8715 DSCF/MMBTU

ARCO ALASKA, INC.
PRUDHOE BAY CENTRAL LABORATORY
ANALYSIS REPORT

Page 45 of 109

SAMPLE# E26581 ARCHIVE# G69K81:ZA

LOCATION, COMPANY,
KUFARUK ARCO

SAMPLE MONTH, DAY, YEAR, HOUR, SAMPLE DATE

9 20 1983 2000

KCM	WPM	CYC	24 SEP	JMS	EWK
VM					SLP
TIA			SEP 27 1983		CC.
Info		RC/CE			File

SAMPLE DESCRIPTION

FUEL GAS AT DRILLSITE 1-Y SAMPLED AT SCRUBBER

TEMP, SAMPLE PSIG, LINE PSIG, METER#

60 150 150 **

REQUESTOR

A. SCHUYLER

PROPERTY	VALUE	
NITROGEN	.22	MOL %
#METHANE	85.34	MOL %
CARBON DIOXIDE	.94	MOL %
ÐANE	7.19	MOL %
PROpane	3.78	MOL %
ISO-BUTANE	.58	MOL %
N-BUTANE	1.23	MOL %
ISO-PENTANE	.27	MOL %
N-PENTANE	.28	MOL %
C6+	.16	MOL %
HYDROGEN SULFIDE	0	PPM PRESENT
GROSS DRY (IDEAL GAS)	1172.6	BTU/CF
NET (IDEAL GAS)	1061.5	BTU/CF
GROSS SATURATED IDEAL	1152.2	BTU/CF
SP GRAVITY (CALC.)	.676
SP GRAVITY (MEAS.)	.679

BTU VALUES ARE ON AN IDEAL BASIS AT 14.696 PSIA AND 60 DEG F

COMMENTS:

.....
.....
.....
.....

COMPLETED BY: 

REVIEWED BY: 

D.SAMPERT/L.MATSON
K.KEYS/F.LOVE
S.KRUSE/D.KILAND
LAB/PROJECT/FILE

ARCO ALASKA, INC. Page 46 of 109
 PRUDHOE BAY CENTRAL LABORATORY
 ANALYSIS REPORT

SAMPLE# E26582 ARCHIVE# G69L82:ZA

KCM	WPM	CVC	AJS	JMS	LWK
		124	SEP	1983	
VM					SLP
TLA	SEP 27 1983			CC.	
Info	RC/CE			File	
Copy	Re- furn In Mo See Ham Edie Dis- card				File

LOCATION, KUPARUK COMPANY, ARCO
 SAMPLE MONTH, DAY, YEAR, HOUR, SAMPLE NUMBER, GAS TO TURBINE 'C'
 9 21 1983 1500

SAMPLE DESCRIPTION KUPARUK FUEL GAS TO TURBINE 'C'
 TEMP, SAMPLE PSIG, LINE PSIG, METER#
 147 190 190 **

REQUESTOR

A. SCHUYLER

ATO 1932

PROPERTY	VALUE	
NITROGEN	.22	MOL %
#METHANE	84.16	MOL %
CARBON DIOXIDE	.96	MOL %
ÐANE	7.73	MOL %
PROPANE	4.21	MOL %
ISO-BUTANE	.64	MOL %
N-BUTANE	1.36	MOL %
ISO-PENTANE	.28	MOL %
N-PENTANE	.29	MOL %
C6+	.14	MOL %
HYDROGEN SULFIDE	1	PPM PRESENT
GROSS DRY (IDEAL GAS)	1187.1	BTU/CF
NET (IDEAL GAS)	1075.1	BTU/CF
GROSS SATURATED IDEAL	1166.5	BTU/CF
SP GRAVITY (CALC.)	.686
SP GRAVITY (MEAS.)	.687

BTU VALUES ARE ON AN IDEAL BASIS AT 14.696 PSIA AND 60 DEG F

COMMENTS:

.....

COMPLETED BY: *D*

REVIEWED BY: *D*

D.SAMPERT/L.MATSON
 K.KEYS/F.LOVE
 S.KRUSE/D.KILAND
 LAB/PROJECT/FILE

Fuel Analysis, F Factor & Lbs/MMBtu

Reference: EPA, Code of Federal Regulations; 40 FCR 60.45

Method: EPA F factor was calculated from the fuel analysis for percent weight carbon, hydrogen, nitrogen, oxygen, sulfur and calorific value. The F factor was then used to calculate lbs/MMBtu emission factors.

Calculations:

$$F = (\text{SDCF } @ 68^\circ\text{F/MMBtu}) = 10^6 * \frac{3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%)}{\text{Btu/lb fuel}}$$

$$\text{lbs/SDCF} = \text{ppm (dry)} * \text{MW} * 2.59 * 10^{-9}$$

$$\text{lbs/SDCF}_0 (@ \text{zero \%O}_2) = \text{lbs/SDCF} * \frac{20.9}{20.9 - \%O_2}$$

$$\text{lbs/MMBtu} = \text{lbs/SDCF}_0 * F$$

$$\text{MW(NOx)} = 46 \text{ grams/mole}$$

SOURCE OPERATION DATA

General Purpose Worksheet

Subject	DS 14 HEATER TEST	Page No.	01
File		By	AJS
		Date	9/20/83

<u>TIME</u>	<u>TEMP IN</u>	<u>TEMP OUT</u>	<u>DESIGN</u>
1637	98°F	118°F	14.2 MSCF/HR
1905	97°F	117°F	

21 psig

DEW POINT - 27° PRESSURE: 29.88"

AMBIENT TEMP - 38°

WR10

WELL TEST REPORT

09/20/83 10:53:36

WELL	DATE	TIME	PROD COMP	TEST PSIU	TEST PSIU	TEST PSIU	TEST CHK	OIL STBD	WTR STBD	TEST DATA		FURN. GAS MSCFD	TOTAL WTR	FURN. GOR SCF/STB	TOTAL GLR SCF/STB	LIFT MSCFD	TEST TIME	API OIL	TIDUHS SYALE	TPLL P	
										STBD	STBD										
IY- 1	09-12-83	1715	280	280	245	176		906	0	640	0	706	706	0	24.0	24.1	N M N N				
IY- 2	09-03-83	0530	230	230	210	176		2634	0	2720	0	1033	1033	0	24.0	25.0	N M N N				
IY- 3	09-11-83	1430	340	350	265	176		3667	0	3651	0	1566	1566	0	12.0	24.4	N M N N				
IY- 4	09-04-83	0945	275	265	239	176		3347	0	4902	0	1465	1465	0	24.0	25.2	N M N N				
IY- 5	09-05-83	1600	280	289	253	176		1388	0	2117	0	1525	1525	0	8.0	24.6	N M N N				
IY- 6	09-11-83	0130	360	360	255	176		4160	0	4592	0	1104	1104	0	8.0	25.5	N M N N				
IY- 7	09-13-83	2100	280	320	262	176		5574	0	5980	0	1673	1673	0	12.0	25.0	N M N N				
IY- 8	09-13-83	0600	260	260	176			1260	0	1432	0	1137	1137	0	12.0	24.8	N M N N				
IY- 9	09-16-83	1130	280	285	262	176		1698	0	2027	0	1193	1193	0	12.0	25.9	N M N N				
IY-10	09-10-83	0215	250	280	260	176		2431	0	1857	0	764	764	0	12.0	25.5	N M N N				
IY-11	09-18-83	0220	280	225	265	176		2111	0	1203	0	370	370	0	8.0	25.1	N M N N				
IY-12	09-09-83	1020	270	280	250	176		3443	0	2751	0	799	799	0	8.0	25.2	N M N N				
IY-13	09-18-83	1000	300	320	260	176		1932	0	1148	0	594	594	0	12.0	25.8	N M N N				
IY-14	09-10-83	1530	180	190	280	176		313	2	658	1	2099	3702	509	10.0	25.4	N M N N				
IY-15	09-15-83	2100	280	270	240	176		2345	0	1183	0	305	305	0	24.0	25.2	N M N N				
IY-16	09-05-83	1700	230	240	235	176		1113	0	580	0	521	521	0	24.0	23.7	N M N N				
##					29079	2															

3+7 production to be shut-in during test

fluid = 29,081 bbl/day

192,000 liter/hr.

ARCO DS1V

start 4:53 PM end 5:10 PM

ADDRESS												
CITY	STATE	ZIP										
PHONE	SOURCE ID NUMBER											
PROCESS EQUIPMENT <i>Process Crude heater</i>	OPERATING MODE <i>100% continuous</i>											
CONTROL EQUIPMENT <i>None</i>	OPERATING MODE <i>EDN/H</i>											
DESCRIBE EMISSION POINT												
HEIGHT ABOVE GROUND LEVEL <i>40</i>	HEIGHT RELATIVE TO OBSERVER <i>40</i>											
STANCE FROM OBSERVER <i>60</i>	DIRECTION FROM OBSERVER <i>NE</i>											
DESCRIBE EMISSIONS <i>none</i>												
EMISSION COLOR <i>clear</i>	PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> PUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>											
WATER DROPLETS PRESENT <i>No</i>	IS WATER DROPLET PLUME <i>Attached</i> <input checked="" type="checkbox"/> ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>											
AT WHAT POINT IN THE PLUME WAS OPACITY DETERMINED												
DESCRIBE BACKGROUND <i>Blue Sky</i>												
BACKGROUND COLOR <i>Blue Sky</i>	SKY CONDITIONS <i>clear</i>											
WIND SPEED <i>0</i>	WIND DIRECTION <i>None</i>											
AMBIENT TEMPERATURE <i>53°F</i>	RELATIVE HUMIDITY <i>20%</i>											
SOURCE LAYOUT SKETCH			DRAW NORTH ARROW									
<p>X EMISSION POINT</p> <p>OBSERVER'S POSITION</p> <p>20' 10'</p>												
<p>AVERAGE OPACITY FOR HIGHEST PERIOD <i>0</i></p> <p>NUMBER OF READINGS ABOVE 0 % WERE</p>												
<p>RANGE OF OPACITY READINGS</p> <p><i>0</i> MINIMUM <i>0</i> MAXIMUM</p>												
<p>OBSERVER'S NAME PRINTED <i>Robert A. Lessl</i></p>												
<p>OBSERVER'S SIGNATURE <i>Robert A. Lessl</i></p>												
<p>ORGANIZATION <i>PEDCo Environmental Inc</i></p>												
<p>I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS</p>												
<p>SIGNATURE <i>Robert A. Lessl</i></p>												
<p>TITLE <i>!!</i></p>												
<p>DATE <i>11/1/83</i></p>												
<p>CERTIFIED BY</p>												
<p>VERIFIED BY</p>												
<p>DATE</p>												
<p>DATE</p>												

General Purpose Worksheet

Subject	<u>C TURBINE (C2101C)</u> <th>Page No.</th> <th>Of</th>	Page No.	Of
File		By	Date
<u>TIME</u>	<u>INLET (°F)</u>	<u>EXHAUST (°F) and % ad</u>	<u>RPM</u>
1110	38	898 99%	9011 1.5.0
1240	39	904 99.5%	9011 (5.1)
1335	38	928 99.5%	9011 (5.2)
1500	39	914 99.5	9011 (5.1)
			<u>GAS RATE (LBS/H)</u>
			807 MSC
			815.7 MSC
			823.7 MSC
			815.7 MSC

<u>TIME</u>	<u>INLET DUCT pressure</u>	<u>exhaust stack pressure</u>
1110	4.2 " of water	1.5 " of water
1240	4.2	1.5
1335	4.2	1.5
1500	4.2	1.5

94 D.P.R > 6°
D.P. = 31°

34.72" = BAROMETRIC PRESSURE

ONE-DAY ANALOG HISTORY
ONE-DAY ANALOG HISTORY

POINT ID: 199 NAME: AI-S1011C

NOTE!! HI, AVG, AND LO=0.00 THEN SYSTEM WAS DOWN

TRB C HP SHFT SPEED

CURRENT VALUE 99.66 PCT

TIME	HIGH	AVERAGE	LOW	TIME	HIGH	AVERAGE	LOW
1000	100.04	99.55	99.06	0300	99.74	99.33	98.99
1600	99.96	99.90	99.36	0400	99.66	99.35	99.14
1000	99.96	99.94	99.89	0500	99.66	99.31	99.06
1800	99.96	99.93	99.89	0600	99.66	99.36	98.99
1000	100.26	99.91	99.51	0700	99.59	99.34	98.99
2000	100.26	99.88	99.66	0800	99.66	99.36	99.14
2100	101.16	99.45	94.71	0900	99.51	99.36	99.14
2000	99.96	99.65	98.99	1000	99.66	99.35	99.14
2300	99.81	99.37	99.14	1100	99.66	99.37	99.21
0000	99.59	99.35	99.14	1200	99.59	99.37	99.14
0100	99.59	99.33	99.14	1300	99.66	99.40	99.06
0200	99.51	99.32	99.06	1400	99.66	99.37	99.06

ENTER POINT NAME OR NUMBER THEN PRESS FUNCTION KEY 1 FOR ANOTHER HISTORY
FUNCTION KEY 2 FOR HARD COPY
FUNCTION KEY 3 TO RETURN TO ANALOG HISTORY MENU

ONE-DAY ANALOG HISTORY
ONE-DAY ANALOG HISTORY

ID: 201 NAME: AI-T1116C

NOTE!! HI, AVG, AND LO=0.00 THEN SYSTEM WAS DOWN

TURB C AVG EXHAUST TEMP

CURRENT VALUE 889.47 DEG F

TIME	HIGH	AVERAGE	LOW	TIME	HIGH	AVERAGE	LOW
1000	971.57	923.89	866.71	10300	889.47	874.14	854.51
1600	973.20	965.50	926.05	10400	889.47	876.12	861.83
1800	973.20	971.31	969.94	10500	878.09	869.66	856.95
1900	970.76	969.20	966.69	10600	891.91	875.57	851.26
2000	969.13	965.92	953.69	10700	885.40	870.51	847.20
2100	967.51	959.38	938.24	10800	891.09	875.69	848.82
2200	967.51	912.27	741.52	10900	912.23	892.15	878.09
2300	944.74	930.04	869.14	11000	904.10	890.10	852.89
2400	937.43	898.83	862.64	11100	904.91	894.83	876.46
0000	910.60	884.93	867.52	11200	915.48	898.00	878.90
0100	894.34	881.35	867.52	11300	924.42	911.28	895.97
0200	892.72	877.14	861.02	11400	917.11	904.15	890.28

ENTER POINT NAME OR NUMBER THEN PRESS FUNCTION KEY 1 FOR ANOTHER HISTORY
FUNCTION KEY 2 FOR HARD COPY
FUNCTION KEY 3 TO RETURN TO ANALOG HISTORY MENU

2^d Stage 4487 HP1st Stage 9316 HP

14803

ONE-DAY ANALOG HISTORY
ONE-DAY ANALOG HISTORY

POINT: 192 NAME:AI-T1117C

NOTE!! HI, AVG, AND LO=0.00 THEN SYSTEM WAS DOWN

TRB C INLT AIR TEMP

CURRENT VALUE 39.83 DEG F

TIME	HIGH	AVERAGE	LOW	TIME	HIGH	AVERAGE	LOW
1500	48.27	46.84	44.21	10300	37.64	36.02	34.51
1600	48.58	47.17	46.08	10400	37.64	36.38	34.51
1700	48.27	46.69	45.14	10500	36.08	34.87	33.26
1800	46.08	43.62	40.14	10600	35.14	34.03	32.95
1900	40.45	39.89	39.20	10700	35.45	34.90	34.51
2000	40.14	39.30	38.58	10800	35.76	34.30	33.89
2100	39.52	38.84	37.95	10900	39.20	37.42	35.45
2200	41.70	40.21	38.27	11000	39.52	38.76	37.95
2300	41.08	39.87	37.95	11100	40.14	39.31	38.58
0000	41.39	40.13	36.08	1200	41.70	40.27	39.20
0100	40.77	38.58	35.76	1300	43.27	40.78	39.52
0200	39.20	37.62	36.08	1400	43.58	41.74	40.14


ENTER POINT NAME OR NUMBER THEN PRESS FUNCTION KEY 1 FOR ANOTHER HISTORY
FUNCTION KEY 2 FOR HARD COPY
FUNCTION KEY 3 TO RETURN TO ANALOG HISTORY MENU

ADDRESS CPF 1 Station C			12:30	124545
CITY	STATE	ZIP		
PHONE	SOURCE ID NUMBER			
PROCESS EQUIPMENT	OPERATING MODE <i>Cont</i>			
CONTROL EQUIPMENT <i>None</i>	OPERATING MODE <i>Cont N/A</i>			
DESCRIBE EMISSION POINT <i>Stack</i>				
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER			
DISTANCE FROM OBSERVER <i>~30'</i>	DIRECTION FROM OBSERVER <i>N</i>			
DESCRIBE EMISSIONS				
EMISSION COLOR <i>clear</i>	PLUME TYPE: CONTINUOUS FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>			
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	IS WATER DROPLET PLUME ATTACHED <input checked="" type="checkbox"/> DETACHED <input type="checkbox"/>			
AT WHAT POINT IN THE PLUME WAS OPACITY DETERMINED <i>N/A</i>				
DESCRIBE BACKGROUND <i>blue sky</i>				
BACKGROUND COLOR <i>blue</i>	SKY CONDITIONS <i>clear</i>			
WIND SPEED <i>~10 mph</i>	WIND DIRECTION <i>NE</i>			
AMBIENT TEMPERATURE <i>N30°F</i>	RELATIVE HUMIDITY <i>N20%</i>			
SOURCE LAYOUT SKETCH		DRAW NORTH ARROW		
COMMENTS			RANGE OF OPACITY READINGS 0 MINIMUM 0 MAXIMUM OBSERVER'S NAME (PRINT) <i>Robert A. Ress</i> OBSERVER'S SIGNATURE <i>Robert A. Ress</i> ORGANIZATION I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE <i>Robert A. Ress</i> TITLE DATE 9/21/83 CERTIFIED BY VERIFIED BY DATE	


SEC M	0	15	30	45	sec M	0	15	30	45
1					31	0	0	0	0
2					32	0	0	0	0
3					33	0	0	0	0
4					34	0	0	0	0
5					35	0	0	0	0
6					36	0	0	0	0
7					37	0	0	0	0
8					38	0	0	0	0
9					39	0	0	0	0
10					40	0	0	0	0
11					41	0	0	0	0
12					42	0	0	0	0
13					43	0	0	0	0
14					44	0	0	0	0
15					45	0	0	0	0
16					46				
17					47				
18					48				
19					49				
20					50				
21					51				
22					52				
23					53				
24					54				
25					55				
26					56				
27					57				
28					58				
29					59				
30	0	0	0	0	60				

AVERAGE OPACITY FOR HIGHEST PERIOD <i>0</i>	NUMBER OF READINGS ABOVE % WERE
RANGE OF OPACITY READINGS 0 MINIMUM 0 MAXIMUM	OBSERVER'S NAME (PRINT) <i>Robert A. Ress</i>
OBSERVER'S SIGNATURE <i>Robert A. Ress</i>	DATE 9/21/83
ORGANIZATION	
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE <i>Robert A. Ress</i> TITLE DATE 9/21/83	CERTIFIED BY VERIFIED BY DATE

SAMPLING PORT AND POINT DESCRIPTION






DRILL SITE 1Y¹
HEATER(S) Parts



SHMF...
FOR ...
TYPICAL

SAMPLE PORT ORIENTATIONS



ELEVATION

NOTES:

PORTS ARE TO BE SA-106 GRB, 3"φ SCH 40, 4" LONG, THREADED ONE END, THREE REQ'D PER STACK, SIX PER HEATER. EACH PORT TO BE CAPPED. EACH CAP TO HAVE FLANGE ACROSS CAP FOR REMOVAL, AND CHAIN.


SUPPORT EYE TO BE 1/2" THICK A-36 PLATE, TWO PER STACK. MATERIAL TO BE SUPPLIED BY AND INSTALLED AT MFS.

REFERENCE BS&G DWG. 32-SRX-A043-02 (P.O. 2244-

PRODUCTION HEATER STACK SAMPLE PORTS FIELD MODIFICATION

ARCO KUPARUK PROJ. L-24750
DRILLSITES 1G, ~~1Y~~ 1F
STEARNS-RUGER '82 SEALIFT

Furnishing CPF-1 Parts



TOP OF
GRAVEL
PAD ECR

BETWEEN
COLUMNS 103 & 101
BETWEEN
COLUMNS 101 & 103

AT DRILL
SITES,
IT IS
TOP OF
TUNDRA.
SOME SPAN
CHECK DRA

**MODULATING DAMPER
ACTUATOR w/ POSITIONER**

1. Add two ports as shown:
2-3" x 4" long, schedule 40, threaded
pipe nipples. They must be
capable of supporting 200#
loading in any direction.
They should be 90° apart,
one on north side, one on west.
Nipples should be capped when
not monitoring.

BETWEEN COLUMNS 101 & 100 311

BETWEEN COLUMNS 101 & 100

...and the world will be at peace.

21-16-53

10. The following table gives the number of hours worked by each of the 1000 workers.

卷之三

10. The following table gives the number of hours worked by each of the 100 workers.

10. The following table gives the number of hours worked by each of the 1000 workers.

10. The following table gives the number of hours worked by each of the 1000 workers.

10. The following table gives the number of hours per week spent by students in various activities.

1990-1991
Yearbook

PF-1


卷之三

URBINE.

3/11/21

Inc. 1911

卷之六

Drillsite Heater 1-Y Points


(7 dia. downstream, 4 dia upstream a disturbance)

Point #

inches Away from edge

1	1.0
2	3.5
3	7.1
4	16.9
5	20.5
6	23.0

Further discussion of sampling points in Appendix 6

Turbine CPF-1 (2101C)

(3.5 dia downstream, 8 dia upstream a disturbance in flow)

<u>Point #</u>	<u>inches from edge</u>	<u>Point #</u>	<u>inches from edge</u>
1	1.5	7	46.4
2	4.8	8	54.0
3	8.5	9	59.2
4	12.8	10	63.5
5	18.0	11	67.2
6	25.6	12	70.2

Further discussion of sampling points in App. #6

APPENDIX

1 - 7

APPENDIX I

Example Calculations

Example CalculationsHeater DS-1Y : RUN # 1 \odot 16:20 on 09-20-87 $V_m(\text{std})$: (68°F & 29.92 "Hg std & $K_3 = 17.65 \text{ }^{\circ}\text{R/in Hg}$)

$$V_m = 20.15 \text{ dsf}$$

$$P_{\text{bar}} = 29.92 \text{ "Hg}$$

$$\Delta H = 0.0 \text{ "H}_2\text{O}$$

$$T_m = 45^{\circ}\text{F} = 505 \text{ }^{\circ}\text{R}$$

$$\text{Meter calibration coefficient} = 0.9862$$

$$V_m(\text{sf}) = 20.15 \text{ dsf} * 0.9862 * 17.65 * \frac{(29.92 + \frac{0.08}{13.6})}{505 \text{ }^{\circ}\text{R}} = 20.78 \text{ dsc}$$

$$\% \text{H}_2\text{O} = 100 * B_{ws} = 100 * \frac{0.04717 * 75.3 \text{ gms H}_2\text{O}}{0.04717 * 75.3 \text{ gms H}_2\text{O} + 20.78} = 14.5 \% \text{H}_2\text{O}$$

$$MW(\text{dry}) = 44 * \frac{12.0\%}{100} + 32 * \frac{0.0\%}{100} + 28 * \frac{88.0\%}{100} = 29.92 \text{ gms/mole}$$

$$MW(\text{wet}) = \left[29.92 * \frac{100 - 14.5 \% \text{H}_2\text{O}}{100} \right] + \left[18 * \frac{14.5 \% \text{H}_2\text{O}}{100} \right] = 28.19 \text{ gms/mole}$$

$$V_s (\text{fps}) = 85.49 * 0.80 * 0.17 * \sqrt{\frac{965^{\circ}\text{F} + 460^{\circ}\text{F}}{(29.92 - \frac{0.08}{13.6})(28.19)}} = 15.1 \text{ fps}$$

$$A_s (\text{ft}^2) = \left(\frac{24 \text{ "dia}}{24} \right)^2 * \pi = 3.14 \text{ ft}^2$$

$$Q_s (\text{DSCFM}) = 60(1 - 0.145)(15.1)(3.14)(17.65) \left[\frac{29.92 + \frac{0.08}{13.6}}{7985 + 460} \right] = 889 \text{ DSCF}$$

Note: Actual calculations by computer maintain all #'s to 12 significant figures while some answers include only 2 sig figs.

Example Calculations (Con't)

(Heater PS-1Y : RUN #1)

$$\boxed{\text{lbs/hr (NO}_x\text{)}} = \text{ppm} * \text{DSCFM} * \text{MW} * 1.605 * 10^{-7}$$

$$= 53 * 920 * 46 * 1.605 * 10^{-7} = \boxed{0.360 \text{ lbs/hr}}$$

$$\boxed{\text{F-factor (DSCF/MMBtu)}} = \frac{(3.64)\%H + (1.53)\%C + (0.57)\%S + (0.14)\%N - (0.46)\%O}{\text{Btu/lb}} * 10^6$$

$$= \frac{(3.64)(22.61) + (1.53)(75.53) + (0.57)(0) + (0.14)(0.32) - (0.46)(1.54)}{22,648} * 10^6$$

$$= \boxed{8707 \text{ SDCF/MMBtu}}$$

$$\boxed{\text{lbs/MMBtu}} = \text{PPM} * \left[\frac{20.9}{20.9 - \%O_2} \right] * \text{MW} * \text{F} * 2.59 * 10^{-9} = \boxed{0.055 \text{ lbs/MMBtu}}$$

$$= 53 * \left[\frac{20.9}{20.9 - 0.1} \right] * 46 * 8707 * 2.59 * 10^{-9} //$$

APPENDIX 2

NOx Emission Standard For Gas Turbine

Calculated Allowable NOx Emission for Stationary Gas Turbines

Ref: Environmental Protection Agency, Code of Federal Regulations,
Title 40, Part 60. Subpart GG, 60.332, 1981

Equation:

$$\text{STD} = 150 \left(\frac{14.4}{Y} \right)$$

where: STD = allowable NOx emissions (percent by volume at 15% O₂ and on
a dry basis)

Y = manufacturer's rated heat rate at manufacturer's rated load
(kilojoules per watt hour)

Calculations:

$$9550 \text{ BTU/Hphr} = \text{manufacture rating } 1/$$

$$1.4137 * 10^{-3} (\text{hphr}) \text{ (kilojoules)/(BTU)(w-hr)}$$

$$\text{STD} = 150 \left(\frac{14.4}{9550 - (1.4137 * 10^{-3})} \right)$$

$$\text{STD} = 159.9 \text{ ppm @ 15\% O}_2$$

1/ This rating provided by Alan Schuyler of Arco based on manufacturers efficiency graphs and actual operating conditions.

GENERAL ELECTRIC MODEL M3142(J) 14600 HP* GAS TURBINE²

ESTIMATED PERFORMANCE


COMPRESSOR INLET TEMPERATURE 30°F (-1.1°C)COMPRESSOR INLET PRESSURE 14.7 PSIA (1.0133 BAR)

FUEL		*NATURAL GAS	DISTILLATE OIL
DESIGN SHAFT OUTPUT	HP	14 600	14 250
DESIGN HEAT RATE (LHV)	BTU/HP-HR	9 530	9 680
DESIGN HEAT CONSUMPTION (LHV)	BTU/HR	139.1×10^6	137.9×10^6
DESIGN AIR FLOW	LBS/HR		415,000
DESIGN SHAFT SPEED	RPM		6 500

NOTES:

1. ALTITUDE CORRECTION ON CURVE 418HA418.
2. AMBIENT TEMPERATURE CORRECTION ON CURVE 471HA282.
3. PRESSURE DROP EFFECTS:

% EFFECTS	HP.	HR
4" H ₂ O INLET	-1.8	+0.8
4" H ₂ O EXHAUST	-0.8	+0.8
4. FOR EACH 4" H₂O PRESSURE DROP INCREASE EXHAUST TEMP. BY 2°F.
5. OPERATION ON CONSTANT HIGH PRESSURE SET SPEED CONTROL.



GENERAL ELECTRIC MODEL M3142(J) 14600 HP* GAS TURBINE²

ESTIMATED PERFORMANCE

COMPRESSOR INLET TEMPERATURE 59°F (15°C)COMPRESSOR INLET PRESSURE 14.7 PSIA (1.0133 BAR)


FUEL

		*NATURAL GAS	DISTILLATE OIL
DESIGN SHAFT OUTPUT	HP	14600	14250
DESIGN HEAT RATE (LHV)	BTU/HP-HR	9530	9680
DESIGN HEAT CONSUMPTION (LHV)	BTU/HR	139.1×10^6	137.9×10^6
DESIGN AIR FLOW	LBS/HR		415,000
DESIGN SHAFT SPEED	RPM		6500

NOTES:

1. ALTITUDE CORRECTION ON CURVE 418HA418.
2. AMBIENT TEMPERATURE CORRECTION ON CURVE 471HA282.
3. PRESSURE DROP EFFECTS:

% EFFECTS	HP	HR
4" H ₂ O INLET	-1.8	+0.8
4" H ₂ O EXHAUST	-0.8	+0.8
4. FOR EACH 4" H₂O PRESSURE DROP INCREASE EXHAUST TEMP. BY 2°F.
5. OPERATION ON CONSTANT HIGH PRESSURE SET SPEED CONTROL.



GENERAL ELECTRIC MODEL M3142(J) 14600 HP* GAS TURBINE²

ESTIMATED PERFORMANCE

COMPRESSOR INLET TEMPERATURE 90°F (32.2°C)
 COMPRESSOR INLET PRESSURE 14.7 PSIA (1.0133 BAR)


FUEL

		*NATURAL GAS	DISTILLATE OIL
DESIGN SHAFT OUTPUT	HP	14 600	14 250
DESIGN HEAT RATE (LHV)	BTU/HP-HR	9 530	9 680
DESIGN HEAT CONSUMPTION (LHV)	BTU/HR	139.1×10^6	137.9×10^6
DESIGN AIR FLOW	LBS/HR		
DESIGN SHAFT SPEED	RPM	415,000	6 500

NOTES:

1. ALTITUDE CORRECTION ON CURVE 418HA418.
2. AMBIENT TEMPERATURE CORRECTION ON CURVE 471HA282.
3. PRESSURE DROP EFFECTS:

% EFFECTS	HP	HR
4" H ₂ O INLET	-1.8	+0.8
4" H ₂ O EXHAUST	-0.8	+0.8
4. FOR EACH 4" H₂O PRESSURE DROP INCREASE EXHAUST TEMP. BY 2°F.
5. OPERATION ON CONSTANT HIGH PRESSURE SET SPEED CONTROL.



GT-17771


GENERAL ELECTRIC MODEL M3142(J) GAS TURBINE

2

EFFECT OF COMPRESSOR INLET TEMPERATURE ON
MAXIMUM OUTPUT, AIR FLOW AND HEAT RATE AT
100% SPEED

NOTES:

1. HP SHAFT DESIGN SPEED - 7107 RPM
2. LOAD TURBINE DESIGN SPEED - 6500 RPM
3. OPERATION AT CONSTANT HIGH PRESSURE SET SPEED CONTROL.



APPENDIX 3

Test Log

68°F

Arco Alaska9-²⁰~~15~~.83

FS YI

Present: Andy Winkler - Analyzer Jan
 Leslie Johnson - stack
 Bob Russel - Petco for EPA

A.D.E.L.

1230 All back from Lunch

Running calibrations & system calibrations

- 1600 Begin stratification check
- 1620 Begin first EPA #2 & #4
- 1745 Begin Run #3 method #2
- 1800 Begin Run #2 method #4
- 1835 Begin Run #3 method #2 Traverse
- 1918 Begin Run #3 method #4
- 1930 #3 Gas Grab
- 1948 Off stack

Analyzer log

- 1640 Begin Run #1 NOx O₂
- 1715 Run #1 completed
- 1730 Begin Run #2 NOx, O₂
- 1735 Crane operator radio interference per jumped chart
- 1815 Begin Run #2 second try
- 1845 End " NOx; O₂
- Calibrate
- 1900 Begin Run #3 NOx; O₂
- 1935 Fini

Arco Alaska 9/21/83 Compressor F=0 (not for)

Y = 14.14 vsua.

Present Robert A. Ressl PEDCO Enviro Gas lift compressor C
0800 on-site Inc. CPF I site

Hot permits issued

- 1111 Begin sampling O₂ traverse plus run #1 6m/m/point 16 total points
 1116 Begin Run #1 EPA #4 H₂O trave
 1120 " " Traverse
 1305 Finished O₂ stratification / Run #1 A+B
 1215 Begin Run #2 EPA #4 H₂O trave
 1235 " " " #2 Velocity traverse
 1325 Begin NOx/O₂ traverse Run #2 (West Port)
 1354 #2 H₂O trave begin
 1400 Run #2 NOx/O₂ finished
 1412 Run #3 Velocity profile
 1415 Run #3 NOx/O₂ traverse (West Port) begun
 1435 " " " finished
 1500 off stack (-23°F w/ chill factor)
 Pack up all equipment shipped through Arco.

APPENDIX 4

Raw Field Data

Field Data Sheet

Client: ARCO Alaska

Unit: Heater-Y1

Report #: 1781

Date: 9-20-83

Site # 1 Time: 16:20 - 16:50

Pitot # 5330 Cp 0.80 Mfr# 635 mcf 0.9862
Temp Unit# Mag# 376 Td — H:AP/Loop /
Duct dia 24.0 (ins) Coup (ins) Bef/Aft / Static -0.08
(3.14 ft²)

Impingers	Final	Tare	Net
1			
2	497.68	422.35	75.33
3 Log Grmby	170	100	
4 Sm Grmby	52	50	
5 K.O.		-	
6 Silica Gel	275.68	272.35	
	Total	75.33	

Integrated Gas Bag #

CO ₂	12.0
O ₂	0.0
N ₂	
CO	

V_m std _____
Total _____
Mw (wt%) _____
P_{0 Iso} _____

SDLFA _____

V_m 20.15 * mcf = V_m corrected _____
Time (min) —

NO₂ —
P_{bar} 29.92
P_d —
T_d 965
ΔP 0.03
V_d 45
T_m 45
ΔH 0.0

$$V_m \text{ (initial)} = 575.95$$

$$V_m \text{ (final)} = 596.10$$

$$20.15$$

Site # 2 Time: 18:00 - 18:25

Pitot # 5330 Cp 0.80 Mfr# 635 mcf 0.9862
Temp Unit# Mag# 376 Td — H:AP/Loop /
Duct dia 24.0 (ins) Coup (ins) Bef/Aft / Static -0.06

Impingers	Final	Tare	Net
1			
2			
3			
4 Log Grmby	128.0	100.0	28.0
5 Sm Grmby	53.0	50.0	3.0
6 Silica Gel	290.0	275.8	14.2
	Total	45.2	

Integrated Gas Bag #

CO ₂	12.3
O ₂	0.0
N ₂	
CO	

J_m std _____
Total O₂ _____
Mw (wt%) _____
P_{0 Iso} _____

SDLFA _____

18.50
V_m 20.15 * mcf = V_m corrected _____
Time (min) —

NO₂ —
P_{bar} 29.92
P_d —
T_d 970
ΔP 0.05
V_d 38
T_m 45
ΔH 0.0

$$V_m \text{ (initial)} = 596.50$$

$$V_m \text{ (final)} = 615.00$$

$$20.15$$

Field Data Sheet

Client: Arco Alaska

Unit: 1781

Report #: Heater Y1 Date: 9-20-83

Site # 3 Time: 18:35 - 19:10

Pitot # 5330 Cp 0.80 Mact# 635 mcf 0.9862
 Temp Unit# mag 376 Td H:AP/Loop /
 Duct dia 24.0 (ins) Coup. (ins) Bef/Aft 5/7 Static -0.07

Impingers	Final	Tare	Net
1	<u>474.75</u>	<u>415.25</u>	<u>59.50</u>
2			
3	<u>Cg Grubg</u>	<u>152</u>	<u>100</u>
4	<u>Sm Grubg</u>	<u>54</u>	<u>50</u>
5	<u>K.O.</u>	<u>-</u>	<u>-</u>
6	<u>Silica Gel</u>	<u>2798</u>	<u>2766.3</u>
	Total		<u>59.5</u>

Integrated Gas Bag #
 CO₂ 12.4
 O₂ 0.0
 N₂
 CO

V_m std
 6H₂O
 m_{fuel}
 10 Iso

SDLFA

V_m 17.95 * mcf = V_m corrected
 Time(min)
 NO₂
 P_{bar} 29.92
 P_d
 T_d 960
 ΔP 0.04
 V_d
 T_m 37
 ΔH 0.0

$$V_m \text{ (final)} = 634.00$$

$$V_m \text{ (initial)} = \frac{616.05}{17.95}$$

Site # Time:

Pitot # Cp Mact# mcf
 Temp Unit# mag# Td H:AP/Loop /
 Duct dia (ins) Coup. (ins) Bef/Aft Static

Impingers	Final	Tare	Net
1			
2			
3			
4			
5	<u>K.O.</u>		
6	<u>Silica Gel</u>		
	Total		

Integrated Gas Bag #
 CO₂
 O₂
 N₂
 CO

V_m std
 Total₂O
 m_{fuel}
 10 Iso

SDLFA

V_m * mcf = V_m corrected
 Time(min)
 NO₂
 P_{bar}
 P_d
 T_d
 ΔP
 V_d
 T_m
 ΔH

INITIAL MOLECULAR WEIGHT & PERCENT WATER

CLIENT: Arco Alaska

SITE: DS YI (Drill site) South Stack West Port

DATE: September 20, 1983 1620 hr beginPressure

Barometric	<u>29.92</u>	"Hg
Static	<u>-0.03</u>	"H ₂ O
Duct (absolute)	<u> </u>	"Hg
Orifice (Δ H)	<u>0.0</u>	"H ₂ O

Temperature

Standard	<u>68</u>	°F
Duct	<u>97.2</u>	°F
Wet Bulb	<u>—</u>	°F
Meter	<u>45</u>	°F 47.4542
Meter #	<u>635</u>	°F 1.011

Water Collection

Final Weight	<u>497.68</u>	g
Tare Weight	<u>422.35</u>	g
Net	<u>75.33</u>	g

M _F	<u>534.75</u>	596.19
M _I	<u>575.95</u>	15 = 0.72 CFM
Meter Volume	<u>20.04</u>	20.3 CF 0.011 ccn. "Hg

RESULTS:

<u>Lg grnbj</u>	<u>170</u>	<u>Tare</u>	<u>wet</u>
<u>smgrnbj</u>	<u>100</u>		
<u>KO.</u>	<u>50</u>		
	<u>—</u>		

275.68272.35272.35 less Tare272.35 gm
netOrsat Analysis

CO ₂	<u>12.0</u>	% Volume (Dry)
O ₂	<u>0.0</u>	% Volume (Dry)
CO	<u>—</u>	% Volume (Dry)
N ₂	<u>88.0</u>	% Volume (Dry)

CO	<u> </u>	ppm Volume (Dry)
		by Dräger tube

Initial Water (By Procedure #)

H ₂ O	<u> </u>	% Volume
MW	<u> </u>	(wet)

Dew Point Temp. °F

INITIAL MOLECULAR WEIGHT & PERCENT WATER

CLIENT: Arco Alaska

SITE: Flow station Y1

DATE: 9/20/83 Begin 1800 hr

Pressure

Barometric	<u>29.12</u>	"Hg
Static	<u>(-)+0.06</u>	"H ₂ O
Duct (absolute)	<u> </u>	"Hg
Orifice (Δ H)	<u>0.0</u>	"H ₂ O

Temperature

Standard	<u>68</u>	°F
Duct	<u>972</u>	°F
Wet Bulb	<u>—</u>	°F
Meter	<u>40 36.38</u>	°F

Water Collection

Final Weight	<u>471.0</u>	g
Tare Weight	<u>425.8</u>	g
Net	<u>45.2</u>	g

MR 615.00
 M₁ 596.50 18.50 + 1.07 = 1.16
 Leat查克
 Meter Volume _____ CF 0.005 Lts.
 V_{mstd} _____ CF @ 10° Hg

RESULTS:

	Flow	Time
H ₂ O	1.21	100
SO	52	50
KO	1	—
S ₁ G ₀₂	290.0	2758

Orsat Analysis

CO ₂	<u>12.3</u>	% Volume (Dry)
O ₂	<u>0.0</u>	% Volume (Dry)
CO	<u> </u>	% Volume (Dry)
N ₂	<u>87.7</u>	% Volume (Dry)

CO _____ ppm Volume (Dry)
by Dräger tubeInitial Water (By Procedure # _____)H₂O _____ % Volume
MW _____ (wet)

Dew Point Temp. _____ °F

INITIAL MOLECULAR WEIGHT & PERCENT WATER

CLIENT: Arco Alaska

SITE: Flow Station Y1 - South ~~Stack~~

DATE: 9/20/83 1918hr Run #3

	<u>Pressure</u>	<u>Temperature</u>
Barometric	<u>29.92</u> "Hg	Standard <u>68</u> °F
Static	<u>-0.07</u> "H ₂ O	Duct <u>960</u> °F
Duct (absolute)	<u>28.91</u> "Hg	Wet Bulb <u>—</u> °F
Orifice (ΔH)	<u>0</u> "H ₂ O	Meter <u>39 37</u> °F

Water Collection

Final Weight	<u>474.75</u> g
Tare Weight	<u>416.25</u> g
Net	<u>58.50</u> g

MF	<u>634.00</u>
MI	<u>616.05</u> 17.95
Meter Volume	<u>18.11</u> CF 0.008 cfm
Vmstd	<u>—</u> CF 67 "Hg

Leak Ch.

0.5

RESULTS:Orsat Analysis 1930 hr

CO ₂	<u>12.4</u> % Volume (Dry)
O ₂	<u>0.0</u> % Volume (Dry)
CO	<u>—</u> % Volume (Dry)
N ₂	<u>87.6</u> % Volume (Dry)

CO	<u>—</u> ppm Volume (Dry) by Dräger tube
----	---------------------------------------------

Initial Water (By Procedure #)

H ₂ O	<u> </u> % Volume
MW	<u> </u> (wet)

Dew Point Temp. °F

DATA: Arco Alaska - Drill site X 1Date 9/20/83Time 1615Run # 1

Description: 2, Four (4) inch male ports correctly located 90° apart on a horizontal plane, approximately 7 dia. after and 5 dia before

Duct Diameter 24 inches Area 3.14 ft^2 adisturbance in the fl.

Rectangular duct X SH₂O MW Duct Static Pressure -0.08 inches H₂OPitot Tube # 5330Standard Conditions 68 °F & 29.92 "HgMag Box # 376Pitot Tube Coefficient 0.718Handitemp # 553

34 14 100% 14

Trav. Pt.	Ins. Edge	South Stack				North Stack +0.01 static				
		From Temp °F	N West Port ΔP In.	Vd ft/sec	N East Temp °F	ΔP In.	Vd ft/sec	S. West Port Temp °F	ΔP In.	Vd ft/sec
1	1.0	963	0.03					892	0.02	
2	3.5							892	0.05	
3	2.8		0.03					892	0.05	
4	15.9		0.04					892	0.05	
5	10.0	963	0.04					892	0.05	
6	23.0	963	0.04					892	0.04	
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										

RESULTS:

Average Velocity (Vd) _____ FPS Average duct temp. _____ °F

Average Volume Flow Rate Qd _____ ACFM at _____ °F & _____ "Hg

Volume Flow Rate Qstd(wet) _____ SCFM at standard conditions

Volume Flow Rate Qstd(dry) _____ SDCFM at standard conditions

DATA: Arco Alaska - FS-Y1Date 9/29/83Time 1745Run # 2

Description: See Run #1

Duct Diameter 24 inches Area 3.14 ft²

Rectangular duct _____ X _____

SH₂O _____ MW _____Duct Static Pressure +0.06 inches H₂OPitot Tube # 5330Standard Conditions 68 °F & 29.92 "HgMag Box # 376Pitot Tube Coefficient 0.718Handitemp # NewportSouth StackNorth Stack +0.07 static

Trav.	Ins.	N. West Port						S. West Port			S. East Port		
		From Pt.	To Edge	Temp °F	ΔP In.	V _d ft/sec		Temp °F	ΔP In.	V _d ft/sec	Temp °F	ΔP In.	V _d ft/sec
1	1.0	972		0.03				979	0.03		899		
2	3.5	972		0.04				969	0.04				
3	7.1	972		0.06					0.05				
4	16.9			0.07					0.05				
5	20.5			0.05					0.04				
6	23.0	972		0.04				964	0.04				
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													

RESULTS:Average Velocity (V_d) _____ FPS Average duct temp. _____ °FAverage Volume Flow Rate Q_d _____ ACFM at _____ °F & _____ "HgVolume Flow Rate Q_{std(wet)} _____ SCFM at standard conditionsVolume Flow Rate Q_{std(dry)} _____ SDCFM at standard conditions

DATA: Arco Alaska - Drill site Y1Date 9/22/83 Time 1335 Run # 3

Description:

Duct Diameter 24.0 inches Area _____ ft²

Rectangular duct _____ X _____

SH₂O _____ MW _____Duct Static Pressure +0.07 inches H₂OPitot Tube # 5330Standard Conditions 68 °F & 29.92 "HgMag Box # 376Pitot Tube Coefficient 0.798Handitemp # new part 264.1

		South Stack						North Stack +0.08					
Trav.	Ins.	N. West Port			S. West Port			N. West Port			S. West Port		
Pt.	From Edge	Temp °F	ΔP In.	Vd ft/sec	Temp °F	ΔP In.	Vd ft/sec	Temp °F	ΔP In.	Vd ft/sec	Temp °F	ΔP In.	Vd ft/sec
1	1.0	960	0.03					944	0.03				
2	3.5		0.04					946	0.04				
3	7.1		0.05					946	0.05				
4	16.9		0.04					1	0.05				
5	20.5		0.03					946	0.04				
6	23.0		0.03					946	0.03				
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													

RESULTS:

Average Velocity (Vd) _____ FPS Average duct temp. _____ °F

Average Volume Flow Rate Qd _____ ACFM at _____ °F & _____ "Hg

Volume Flow Rate Qstd(wet) _____ SCFM at standard conditions

Volume Flow Rate Qstd(dry) _____ SDCFM at standard conditions

Field Data Sheet

Client: ARCO Alaska

Unit: Turbine C-CPF Report #: 1781 Date: 9-21-83

Site # 1 Time: 11:20 - 12:35

Pitot # 5330 Cp 0.80 Mact# 635 mcf 0.9862
 Temp Unit# Mag# 376 Td — H:AP/Loop /
 Duct dia 72.0 (ins) Coup (ins) Bcf/Aft 3.5/8 Static 0.70
 (28.27 ft²)

Impingers	Final	Tare	Net
1	459.61	444.16	15.45
2			
3 La Grinby	109	100	
4 Sh Grinby	52	50	
5 K.O.	—	—	
6 Silica Gel	299.81	294.76	
	Total	15.45	

Integrated Gas Bag #

CO ₂	1.5
O ₂	16.5
N ₂	—
CO	—

V_m std
10H₂O
mH₂O
10 I_{so}

SDCFM (93.545)

V_m 21.00 • mcf = V_m corrected
 Time(min) —
 NO₂ —
 P_{bar} 29.65
 P_d —
 T_d 895
 ΔP 2.70
 V_d (148.7)
 T_m 45
 dH 0.0

$$V_m \text{ (final)} = 656.15$$

$$V_m \text{ (initial)} = \frac{635.15}{21.00}$$

Site # 2 Time: 12:15 - 12:35

Pitot # 5330 Cp 0.80 Mact# 635 mcf 0.9862
 Temp Unit# Mag# 376 Td — H:AP/Loop /
 Duct dia 72.0 (ins) Coup (ins) Bcf/Aft / Static 0.76

Impingers	Final	Tare	Net
1			
2	470.91	448.61	22.3
3 La Grinby	119	100	
4 Sh Grinby	52	50	
5 K.O.	—	—	
6 Silica Gel	299.81	293.61	
	Total	22.3	

Integrated Gas Bag #

CO ₂	1.5
O ₂	16.6
N ₂	—
CO	—

SDCFM (93.305)

V_m 20.10 • mcf = V_m corrected
 Time(min) —
 NO₂ —
 P_{bar} 29.65
 P_d —
 T_d 895
 ΔP 2.77
 V_d (151.4)
 T_m 45
 dH 0.0

$$V_m \text{ (final)} = 676.55$$

$$V_m \text{ (initial)} = \frac{656.45}{20.10}$$

Client: ARCO Alaska

Field Data Sheet

Unit: Turbine C-C PF1 Report #: 1781

Date: 9-21-83

Site # 3 Time: 13:55 - 14:30

Pitot # 5330 Cp 0.80 Meturb 635 mcf 0.9862
 Temp Unit # Mag # 376 Td _____ H:ΔP/loop /
 Duct dia 72.0 (ins) Coup. (ins) Bcf/att / Static 0.70

Impingers	Final	Tare	Net
1	469.8	444.4	25.4
2	120	100	
3	51	50	
4	-	-	
5	K.O.		
6	Silica Gel	298.8	294.40
	Total		25.4

Integrated Gas Bag # 3

CO ₂	1.9	V _m std	_____
O ₂	16.5	T ₀ H ₂ O	_____
N ₂		M ₀ (w)	_____
CO		T ₀ Iso	_____

SDLFA _____

 $V_m = 20.56 \text{ mcf} = V_m \text{ corrected}$

T_m(m/s) / NO₂ / P_{bar} 29.65
 P_d / T_d 895 / ΔP 2.68
 V_d / T_m 45 / ΔH 0.0

$$V_m (\text{final}) = 698.16$$

$$V_m (\text{initial}) = \frac{677.60}{20.56}$$

Site # Time:

Pitot # _____ Cp _____ meturb _____ mcf _____
 Temp Unit # _____ Mag # _____ Td _____ H:ΔP/loop _____
 Duct dia. _____ (ins) Coup. (ins) Bcf/att _____ Static _____

Impingers	Final	Tare	Net
1	_____	_____	_____
2	_____	_____	_____
3	_____	_____	_____
4	_____	_____	_____
5	K.O.		
6	Silica Gel		
	Total		

Integrated Gas Bag #

CO ₂	V _m std
O ₂	T ₀ H ₂ O
N ₂	M ₀ (w)
CO	T ₀ Iso

SDLFA _____

 $V_m = \text{mcf} = V_m \text{ corrected}$

T_m(m/s) / NO₂ / P_{bar} / P_d / T_d / ΔP / V_d / T_m / ΔH

INITIAL MOLECULAR WEIGHT & PERCENT WATER

CLIENT: Arco Alaska

SITE: Gas lift Compressor C - CPEI

DATE: 9/21/83

1116 hr - 1235 Run # 1

Pressure

Barometric	<u>29.65</u>	"Hg
Static	<u>7070</u>	"H ₂ O
Duct (absolute)	<u>29.70</u>	"Hg
Orifice (Δ H)	<u>0</u>	"H ₂ O

Temperature

Standard	<u>68</u>	°F
Duct	<u>772</u>	°F
Wet Bulb	<u>55</u>	°F
Meter	<u>45</u>	°F

Water Collection

Final Weight	<u>459.61</u>	g	<u>150</u>	<u>160</u>
Tare Weight	<u>444.16</u>	g	<u>194.11</u>	<u>299.41</u>
Net	<u>15.45</u>	g		

$^{\circ}$ F	<u>656.15</u>	<u>2100</u>
$^{\circ}$ I	<u>635.15</u>	<u>2000</u>
Meter Volume	<u>20.10</u>	CF
Vmstd		CF

RESULTS: 1149 hrOrsat Analysis

CO ₂	<u>1.5</u>	% Volume (Dry)
O ₂	<u>16.5</u>	% Volume (Dry)
CO	<u>32.0</u>	% Volume (Dry)
N ₂		% Volume (Dry)

CO _____ ppm Volume (Dry)
by Dräger tubeInitial Water (By Procedure # ____)H₂O _____ % Volume
MW _____ (wet)

Dew Point Temp. _____ °F

INITIAL MOLECULAR WEIGHT & PERCENT WATER

CLIENT: Arco Mexico

SITE: Gaslift Compressor C CPT

DATE: 7/21/83 1215hr - 1250

Run #2

Pressure

Barometric	<u>29.65</u>	"Hg
Static	<u>+0.76</u>	"H ₂ O
Duct (absolute)	<u>29.71</u>	"Hg
Orifice (ΔH)	<u>0.0</u>	"H ₂ O

Temperature

Standard	<u>68</u>	°F
Duct	<u> </u>	°F
Wet Bulb	<u> </u>	°F
Meter	<u> </u>	°F

Water Collection

Final Weight	<u>470.91</u>	g
Tare Weight	<u>448.61</u>	g
Net	<u>22.30</u>	g

M.W. 2776.2

M.,	<u>676.55</u>	
A,	<u>656.45</u>	20.10
Meter Volume	<u>12.02</u>	CF 0.010 CF
Vmstd	<u> </u>	CF

RESULTS:Orsat Analysis

CO ₂	<u>1.5</u>	% Volume (Dry)
O ₂	<u>16.6</u>	% Volume (Dry)
CO	<u> </u>	% Volume (Dry)
N ₂	<u>81.9</u>	% Volume (Dry)

CO _____ ppm Volume (Dry)
by Dräger tubeInitial Water (By Procedure # _____)H₂O _____ % Volume
MW _____ (wet)

Dew Point Temp. _____ °F

INITIAL MOLECULAR WEIGHT & PERCENT WATER

CLIENT: 11500 Martin

SITE: CPF1 Gas Line Compressor

DATE: 9/21/83 1354 hr - 1430 Run #3

Pressure

Barometric	<u>29.65</u>	"Hg
Static	<u>10.70</u>	"H ₂ O
Duct (absolute)	<u> </u>	"Hg
Orifice (Δ H)	<u>0.0</u>	"H ₂ O

Temperature

Standard	<u>68</u>	°F
Duct	<u> </u>	°F
Wet bulb	<u>-</u>	°F
Meter	<u>45</u>	°F

us

Water Collection

Final Weight	<u>469.75</u>	g
Tare Weight	<u>444.4</u>	g
Net	<u>25.35</u>	g

Mcf = 0.9762

ml	<u>698.16</u>	
Meter Volume	<u>677.60</u>	CF 0.0115
Vmstd	<u>20.07</u>	CF

RESULTS:Orsat Analysis

CO ₂	<u>1.4</u>	% Volume (Dry)
O ₂	<u>16.5</u>	% Volume (Dry)
CO	<u>82</u>	% Volume (Dry)
N ₂	<u> </u>	% Volume (Dry)

CO ppm Volume (Dry)
by Dräger tubeInitial Water (By Procedure #)

H ₂ O	<u> </u>	% Volume
MW	<u> </u>	(wet)

Dew Point Temp. °F

DATA: Gas Line Compressor C - CPF1

Date 7/21/83 Time 1120 Run # 1

Description: Two 3" ports properly located 3.5 diameters after and approximately 8 diameters before a disturbance

Duct Diameter 720 inches Area 28.27 ft²

Rectangular duct X

%H₂O MW

Duct Static Pressure 10.70 ^{Sq in} inches H₂O

Pitot Tube # 550

Standard Conditions 68 °F & 29.92 "Hg

Mag Box # 326

Pitot Tube Coefficient 0.798

Handitemp # Newport

264-1

Trav.	Ins. From Pt.	Temp °F	Upstream Part			Downstream Part			Temp °F	ΔP In.	Vd ft/sec	Temp °F	ΔP In.	Vd ft/sec
			From Edge	ΔP In.	Vd ft/sec	Temp °F	ΔP In.	Vd ft/sec						
1	1.5	892	1.70						892	0.80				
2	4.8		2.40						892	2.40				
3	8.5		2.50						892	2.50				
4	12.4		2.50						892	2.50				
5	16.0		2.60						892	2.60				
6	20.6		2.60						912	3.20				
7	24.4		2.60						892	3.20				
8	28.0		2.60						892	4.20				
9	31.2		2.60						892	3.20				
10	34.5		2.60						892	4.20				
11	37.2		2.70						892	3.40				
12	40.5		2.70						892	4.40				
13									892	3.20				
14									892	2.20				
15									892	2.20				
16									892	2.20				
17									892	2.20				
18									892	2.20				
19									892	2.20				
20									892	2.20				
21									892	2.20				
22									892	2.20				
23									892	2.20				
24									892	2.20				

RESULTS:

Average Velocity (Vd) _____ FPS Average duct temp. _____ °F

Average Volume Flow Rate Qd _____ ACFM at _____ °F & _____ "Hg

Volume Flow Rate Qstd(wet) _____ SCFM at standard conditions

Volume Flow Rate Qstd(dry) _____ SDCFM at standard conditions

DATA: Gas Line Comparison C-CPFEZDate 7/21/83 Time 1235 Run # 2

Description:

See Run #1

Duct Diameter 72.0 inches Area 28.27 ft²Rectangular duct XRH₂₀ MW Duct Static Pressure +0.76 inches H₂₀Pitot Tube # 5522Standard Conditions 68 °F & 29.92 "HgMag Box # 326Pitot Tube Coefficient 0.718Handitemp # NICUPENT
264-1

Trav. Pt.	Ins. From Edge	Wet			Saturated			Dry			Wet		
		Temp °F	ΔP In.	Vd ft/sec									
1	1.5	895	1.20					894	1.80				
2	4.8		2.40							2.20			
3	8.5		3.00							2.30			
4	12.8	895	3.40							2.30			
5	18.0		3.40							2.30			
6	25.6		3.40					894	2.70				
7	46.4		1.40							2.20			
8	54.0		2.10					894	2.70				
9	59.2	895	3.40							2.50			
10	63.5		3.10							2.50			
11	67.2		3.00							2.50			
12	70.5	895	2.10					894	2.30				
13										2.30			
14										2.90			
15										2.90			
16													
17													
18													
19													
20													
21													
22													
23													
24													

RESULTS:

Average Velocity (Vd) _____ FPS Average duct temp. _____ °F

Average Volume Flow Rate Qd _____ ACFM at _____ °F & _____ "Hg

Volume Flow Rate Qstd(wet) _____ SCFM at standard conditions

Volume Flow Rate Qstd(dry) _____ SDCFM at standard conditions

DATA: Gas Lift Compressor C-CPF IDate 9/21/81 Time 1412 Run # 3Description: see Run #1Duct Diameter 12.0 inches Area 28.27 ft²

Rectangular duct _____ X _____

SH₂O _____ MW _____Duct Static Pressure +0.30 inches H₂OPitot Tube #Standard Conditions 68 °F & 29.92 "HgMag Box # 26Pitot Tube Coefficient 0.798Handitemp # Newport
264-1

Trav. Pt.	Ins. From Edge	1165 Pt.			1166 Pt.			1167 Pt.			1168 Pt.		
		Temp °F	Δ P In.	Vd ft/sec									
1	1.5	892	1.0					894	1.80				
2	4.8	892	2.4					894	2.40				
3	8.5	892	2.80					894	2.40				
4	12.8	892	3.20					894	2.40				
5	19.0	892	3.20					894	2.40				
6	25.0	892	3.20					894	2.40				
7	46.4	892	3.80					894	2.40				
8	54.0	892	3.60					894	2.40				
9	57.2	892	3.20					894	2.50				
10	61.5	892	3.20					894	2.40				
11	67.2	892	3.00					894	2.80				
12	73.5	892	2.80					894	2.90				
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													

RESULTS:

Average Velocity (Vd) _____ FPS Average duct temp. _____ °F

Average Volume Flow Rate Qd _____ ACFM at _____ °F & _____ "Hg

Volume Flow Rate Qstd(wet) _____ SCFM at standard conditions

Volume Flow Rate Qstd(dry) _____ SDCFM at standard conditions

APPENDIX 5

Wet Test Equipment Calibration Data

PITOT TUBE CALIBRATION DATAPITOT TUBE IDENTIFICATION NUMBER 5350PITOT TUBE TYPE 9ft initialCALIBRATED BY LJB/FLDATE 9/14/83

$$\bar{C}_P = \frac{\bar{C}_{P\text{A}} + \bar{C}_{P\text{B}}}{2} = 0.798$$

A SIDE CALIBRATION

RUN	ΔP STD	ΔP (S)	C_P (S)	DEV.
1	0.13	0.20	0.798	0.002
2	0.50	0.79	0.788	-0.002
3	0.79	1.20	0.803	0.007
		$\bar{C}_{PA} = 0.796$		AVG. = 0.006

STANDARD DEVIATION OF AVG. DEV. = 0.003 (Must be <.02)

B SIDE CALIBRATION

RUN	ΔP STD	ΔP (S)	C_P (S)	DEV.
1	0.13	0.20	0.798	-0.001
2	0.50	0.77	0.797	-0.002
3	0.79	1.20	0.803	0.004
		$\bar{C}_{PB} = 0.799$		AVG. = 0.002

STANDARD DEVIATION OF AVG. DEV. = 0.002 (Must be <.02)

CALCULATIONS: $| \bar{C}_{P\text{A}} - \bar{C}_{P\text{B}} | = 0.003$ (Must be <.01)AVERAGE DEVIATION = $\frac{1}{3} \left| C_P (\text{S}) - \bar{C}_P (\text{A or B}) \right|$ (Must be <.01)DEVIATION (DEV.) = $C_P (\text{S}) - \bar{C}_P (\text{A or B})$

$$C_P (\text{S}) = C_P (\text{STD}) \sqrt{\frac{\Delta P \text{ STD}}{\Delta P_s}} \quad \text{Where } C_P (\text{STD}) = 0.99$$

MADE PRIOR TO TEST

PUMP METER TEST & CALIBRATION

METER	3.635	STD	STD	STD	STD	STD
DATE	9-14-83					ST
POTEN.	3.553					
AG.G.	100/120V					
BAR	29.78					
N.F.	575.209	3.201				
N.I.	571.800	0				
ICF	3.409	3.201				
T°F	115	91	.			
R°	575	551	.			
"H ₂ O	2.8	1.4				
D°Hg	.21	.10				
P°Hg	29.99	29.88				
SCFM	3.0902	3.0169				
%	-1.48					
EF FACTOR	0.9862					
ON						
OFF						
METER	STD	STD	STD	STD	STD	STD
DATE						ST
POTENT.						
AG.G.						
BAR						
N.F.						
N.I.						
ICF						
T°F						
R°						
"H ₂ O						
D°Hg						
P°Hg						
SCFM						
%						
EF FACTOR						
ON						

MAGNEHELIC GAUGE BOXES

INCLINE ANOMETER	#	CORREC. FACTOR	#	CORREC. FACTOR	#	CORREC. FACTOR	#	CORREC. FACTOR	#	CORREC. FACTOR	CO EFF
ATE	9-14-83										

0 - 5

5.00	4.85	1.03									
4.50	4.40	1.02									
4.00	3.95	1.02									
3.50	3.48	1.01									
3.00	2.94	1.01									
2.50	2.49	1.01									
2.00	1.99	1.01									
1.74	1.74	1.00									
1.48	1.48	1.00									
1.24	1.24	1.00									
1.08	1.08	1.00									
1.0	1.00	1.00									

E

 \bar{x} \sqrt{x}

0 - 1

1.00	.96	1.0f									
.88	.84	1.05									
.65	.62	1.05									
.52	.50	1.04									
.30	.29	1.03									
.22	.21	1.05									
.12	.12	1.00									

E

 \bar{x} \sqrt{x}

MAGNEHELIC GAUGE READINGS WERE COMPARED TO READINGS ON WALL-MOUNTED DRYER INCLINE MANOMETER AS A STANDARD & CALCULATED A CORRECTION FOR INCLINE MANOMETER.

APPENDIX 6

Instrument Calibration Data and Recorder Strip Charts

INSTRUMENT AND CALIBRATION DATA

<u>Analyzer</u>	<u>Range</u>	<u>Zero Gas</u>	<u>Span Gas</u>
Type: NO/NOx			
Manufacturer: Monitor Labs	0-500 ppm	Ambient Air 1/	92.35 2/
Model: 8430			
Serial #: 66			
Type: O ₂			
Manufacturer: Taylor	0-25%	NOx	Ambient Air
Model: 580			
Serial #: 580110100-63			

1/ Ambient Air (Drierite packed tube)

2/ Cylinder #CAL7232 (See certification data)

PLAINFIELDVILLE, PA. 18949

PHONE: 215-766 8861

TWX: 510-665-9344

Date Shipped

0-4-83

OXONECOLOGY
1841 PONTERVILLE HWY
MCKEESFIELD, CA 93308

Our Project No: 321116

Your P.O. No: 3814

Page 1 of 1

ATTN: LESLIE JOHNSON

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES*

(Concentrations are in mole % or ppm)

CAL-7232

Certified Accuracy 1 % NBS Traceable

Analysis Dates: First 4/14/83 Last 8/3/83

Cylinder Number

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST	SECOND
SULFUR DIOXIDE	48.80 ppm	2/3/84	ELECTRO-CHEMICAL	1694, 1693	48.80 ppm	48.80 ppm
NITRIC OXIDE	92.35 ppm	2/3/84	CHEMILUMINESCENCE	1683, 1684	92.34 ppm	92.36 ppm
NITROGEN	BALANCE					

Attachment #7

Cylinder Number _____ Certified Accuracy _____ % NBS Traceable Analysis Dates: First _____ Last _____

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST	SECOND

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No:

Analyst

PENROSE HALLOWELL, JR.


Approved By

FRANCIS E. NEVILL

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBLEND^(R) ■ CALIBRATION & SPECIALTY GAS MIXTURES
 PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA



Oil Inlet
Oil outlet
14.2 MSCFM

Analyzer	Span	Zero
NOx	923 ppm	Ambient
	CAL 9232	Ave
O ₂	Ambient	CAL 9232 N. Normal


Arco Alaska Report #1781
9/20/83 Heater PS 41


Max NOx mixed = 30


AN/FRTS

Comb gas NOx
923 ppm

at









55 SWAN CREEK -> 70 SWAN


100 90 80 70 60 50 40 30 20 10 0




Analyzer	Span	Zero
H ₂ O	92.35	Ambient
	CAL 722	Air

O ₂	Ambient	CAL
	11V	722










CHART NO. 0100-002!


APPENDIX 7

Sampling Photos

HEATER DS 1-Y




Analyzers, manifold and conditioning train (bottom)




Heater stack, Analyzer van below

TURBINE CPF-1 (C2101C)



Velocity Traverse



Wet Sampling Equipment (L) and Analyzer Conditioning Train (R)